WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 81201
Permit No.
Basin 92A

NOTICE OF INTENT NO. 41709

1. OWNER Keith Shelton Construction
MAILING ADDRESS 1550 Kleppe Ln.
Sparks, NV

ADDRESS AT WELL LOCATION
14055 Red Rock Rd.
Reno, NV 89506

2. LOCATION NW ¼ NW ¼ Sec. 29 T 22 (N)S R 19 E Washoe County
PERMIT NO. N/A (Issued by Water Resources) 079-351-04 (Parcel No.) Red Rock Estates # 127 (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☒ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Topsoil		0	2	
Brown Sand		2	14	
Clay and gravel		14	30	
Gray Shale		30	179	
Gray Sandstone		179	540	
Brown Sandy Clay		540	585	
Gray Sandstone		585	700	

Date started 5-3-00, 19
Date completed 5-10-00, 19

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
Approx	11	700	4

8. WELL CONSTRUCTION
Depth Drilled 700 Feet Depth Cased 700 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
12 ¼"	Inches	0	Feet	16	Feet
9 7/8	Inches	16	Feet	673	Feet
6 1/8	Inches	673	Feet	700	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	13	.188	-1	673
5 9/16	9	.188	660	700

Perforations:
Type perforation Mill Slot
Size perforation 1/8" x 3"
From 195 feet to 215 feet
From 435 feet to 455 feet
From 535 feet to 555 feet
From 660 feet to 700 feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 60'
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☒ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 60 feet to 700 feet

9. WATER LEVEL
Static water level 131 feet below land surface
Artesian flow none G.P.M. none P.S.I.
Water temperature cool °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name MILLER & SONS DRILLING CO. (Contractor)
Address P.O. Box 8056 (Contractor)
Reno, NV 89607

Nevada contractor's license number issued by the State Contractor's Board 37915

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1418

Signed Bruce Miller
By driller performing actual drilling on site or contractor

Date 5-28-00

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O) 627