

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 43876

1. OWNER RANDY & MARIE BARNEY ADDRESS AT WELL LOCATION 1310 American Flat Road
 MAILING ADDRESS c/o J&L Builders 10900 Red Rock Rd. Reno, Nevada 89506
 2. LOCATION SW 1/4 NE 1/4 Sec. 33 T. 22N N/S R. 19 E. Washoe County Antelope Valley
 PERMIT NO. 079-420-12 Subdivision Name Red Rock #361
 Issued by Water Resources Parcel No.

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top soil		0	1	1
Gravel boulder & sand		1	4	3
BRown fine sand		4	15	11
Brown sandy clay		15	55	40
Soft zone (NO WATER)		55	57	2
Brown sandy clay		57	81	24
Brown cemented clay		81	91	10
Brown sandy clay		91	105	14
Weathered granite w/ clay streaks		105	169	64
Rusty brown weathered granite		169	186	17
Weathered gray granite harder		186	268	82
Clay zone (soft)		268	273	5
Weathered gray granite		273	290	17
Gray hard granite		290	345	55
Weathered granite with clay streaks		345	385	40
Gray hard granite		385	399	14
Broken fracture granite X		399	421	22
Gray granite		421	425	4

8. WELL CONSTRUCTION 425 Feet
 Depth Drilled 425 Feet Depth Cased 425 Feet

HOLE DIAMETER (BIT SIZE)

From	To
10 Inches	50 Feet
8 5/8 Inches	425 Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8		.188	0	425

Perforations: factory sawed slot
 Type perforation 3/32 x 3 x 5 around
 Size perforation 380 feet to 420 feet

From feet to feet
 From feet to feet
 From feet to feet
 From feet to feet

Surface Seal: Yes No Seal Type: Neat Cement
 Depth of Seal 50 feet Cement Grout
 Placement Method: Pumped Concrete Grout
 Poured

Gravel Packed: Yes No
 From 50 feet to 425 feet

Date started August 7, 2000
 Date completed August 9, 2000

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
20+		

9. WATER LEVEL
 Static water level 320 feet below land surface
 Artesian flow G.P.M. 20+ P.S.I.
 Water temperature cold °F Quality clear

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name WAYNE DRILLING, INC. Contractor
 Address P.O. BOX 12370 Contractor
RENO, NEVADA 89510

Nevada contractor's license number 0022549
 issued by the State Contractor's Board

Nevada driller's license number 923
 issued by the Division of Water Resources the on-site driller

Signed Wayne Drilling, Inc.
 By driller performing actual drilling on site or contractor
 Date August 10, 2000