


STATE OF NEVADA
 DIVISION OF WATER RESOURCES



OFFICE USE ONLY
 Permit No. 81218
 Basin 54

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 43620

1. OWNER Cortez Gold Mines DB-17 ADDRESS AT WELL LOCATION Cortez Gold Minesite,
 MAILING ADDRESS Star Route HC 66-50 south of Crescent Valley, NV.
Beowawe, NV 89821-9708

2. LOCATION NW 1/4 NE 1/4 Sec. 6 T 27N N/S R 47E E Lander County
 PERMIT NO. 57147 issued by Water Resources | N/A Parcel No. | N/A Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition Deepen Abandon Other

4. PROPOSED USE
 Domestic Municipal/Industrial Irrigation Monitor Test Stock

5. WELL TYPE
 Cable Rotary RVC Air Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Alluvium		0	445	445
Gray rock, some brown rock		445	600	155
Gray rock		600	630	30
Gray, brown, black rock		630	660	30
Brown rock		660	800	140
Gray and white rock		800	870	70
Gray and brown rock		870	1130	260
Black rock		1130	1320	190

8. WELL CONSTRUCTION

Depth Drilled 1320 Feet Depth Cased 1314 Feet

HOLE DIAMETER (BIT SIZE)

Inches	From	To	Feet	Feet
38	0	20	0	20
31	20	452	20	452
24	452	1320	452	1320

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
34	134.67	0.375	0	20
26	102.63	0.375	0	452
18	58.94	0.312	0	1320

Perforations:
 Type perforation Louvered
 Size perforation 0.080"

From	To	Feet	Feet
731.5	1314	731.5	1314

Surface Seal: Yes No Seal Type: Neat Cement
 Depth of Seal 450 Cement Grout
 Placement Method: Pumped Poured Concrete Grout

Gravel Packed: Yes No
 From 0 feet to 1320 feet

Date started 6/18/2000 19__
 Date completed 7/1/2000 19__

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailor <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			

9. WATER LEVEL

Static water level 673' 7" feet below land surface
 Artesian flow N/A G.P.M. N/A P.S.I.
 Water temperature Warm °F Quality Fair

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Lang Exploratory Drilling Contractor
 Address P.O. Box 5279 Contractor
Elko, NV 89802-5279
 Nevada contractor's license number issued by the State Contractor's Board 0021975
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2095

Signed Joe Crawford By driller performing actual drilling on-site or contractor
 Date 7/12/2000

BSTL