WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 81265
Permit No.
Basin 734

NOTICE OF INTENT NO. 43816

1. OWNER Clarence Hultgren
MAILING ADDRESS 11290 Beaumont Trail
Lovelock, NV 89419

ADDRESS AT WELL LOCATION 111290 Beaumont Trail
Lot 27 Blk B Phase F of

2. LOCATION ____ 1/4 N1/2 1/4 Sec. 27 T 30N N/S R 33E E Pershing County
PERMIT NO. ____ Issued by Water Resources | 10-521-02 Parcel No. | Humboldt river ranches Subdivision Name

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other ____

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[ ] Air [ ] Other ____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Boulder & clay		0	250	
Boulders & gravel		250	300	50

Date started 5/22/00, 19__
Date completed 5/31/00, 19__

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
50		4 hrs

8. WELL CONSTRUCTION
Depth Drilled 300 Feet Depth Cased 273 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
11	Inches	0	Feet	60	Feet
9-7/8	Inches	60	Feet	130	Feet
7-7/8	Inches	130	Feet	300	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6-5/8		.188	+1	193

Perforations:
Type perforation mill slot
Size perforation 1/8 x 3
From 193 feet to 273 feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 70
Placement Method: [ ] Pumped [X] Poured
Seal Type: [ ] Neat Cement [X] Cement Grout [ ] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 70 feet to 270 feet

9. WATER LEVEL
Static water level 220 feet below land surface
Artesian flow ____ G.P.M. ____ P.S.I.
Water temperature cool °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Humboldt Drilling & Pump Co., Inc. (Contractor)
Address 4675 W. Winnemucca Blvd (Contractor)
Winnemucca, Nevada 89445

Nevada contractor's license number issued by the State Contractor's Board 015234

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1713

Signed [signature] (By driller performing actual drilling on-site or contractor)

Date 6/3/00