

PRINT OR TYPE ONLY  
DO NOT WRITE ON BACK

**WELL DRILLER'S REPORT**  
Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 20315

1. OWNER Contri Const. ADDRESS AT WELL LOCATION On Pecos S + W of Sunset  
MAILING ADDRESS LV NV  
2. LOCATION 1/4 31 21 N/S 62 E Clark County \_\_\_\_\_  
PERMIT NO. DW-1177 Issued by Water Resources | 161-31410-001 Parcel No. | \_\_\_\_\_ Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
4. PROPOSED USE Dewater  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other Socket


6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
<u>Asphalt</u>		<u>0</u>	<u>8"</u>	
<u>Type 2</u>		<u>8"</u>	<u>3'</u>	
<u>Clay w/ sand</u>		<u>3</u>	<u>13</u>	
<u>Silty sand w/ clay lens</u>		<u>13</u>	<u>17</u>	
<u>Clay</u>		<u>17</u>	<u>23</u>	
<u>Silty sand w/ clay</u>		<u>23</u>	<u>37</u>	
<u>Clay</u>		<u>37</u>	<u>46</u>	

23' Temp. Dewatering wells in this parcel

8. WELL CONSTRUCTION  
Depth Drilled 40 Feet Depth Cased 40 Feet  
HOLE DIAMETER (BIT SIZE)  
From 24 Inches To 40 Feet  
Inches Feet Feet  
Inches Feet Feet  
CASING SCHEDULE  
Size O.D. (Inches) Weight/Ft. (Pounds) Wall Thickness (Inches) From (Feet) To (Feet)  
4 PUC 5/8 40 0 40  
Perforations:  
Type perforation slot  
Size perforation 0030  
From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
From 10 feet to 40 feet  
From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
Surface Seal:  Yes  No Seal Type:  
Depth of Seal \_\_\_\_\_  Neat Cement  
Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
Gravel Packed:  Yes  No  
From 0 feet to 40 feet

Date started 9-7-0  
Date completed 9-18-0



7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

9. WATER LEVEL  
Static water level 12 feet below land surface  
Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_

10. DRILLER'S CERTIFICATION  
This well was drilled under my supervision and the report is true to the best of my knowledge.  
Name Griffin Dewatering Contractor  
Address 536 E. Whitland Contractor  
Ontario CA  
Nevada contractor's license number issued by the State Contractor's Board 31246  
Nevada driller's license number issued by the Division of Water Resources, the on-site driller M1968  
Signed [Signature]  
By driller performing actual drilling on site or contractor  
Date 9-19-0