WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

# WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 81285
Permit No.
Basin 212

NOTICE OF INTENT NO. 20315

1. OWNER Contri Const.
MAILING ADDRESS LV NV
ADDRESS AT WELL LOCATION On Pecos S + N of Sunset

2. LOCATION ¼ ¼ Sec. 31 T. 21 N/S R. 62 E Clark County
PERMIT NO. DW-1177 Issued by Water Resources
161-31410-001 Parcel No.
Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE Dewater
☐ Domestic ☐ Irrigation ☐ Test
☒ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☒ Other Bucket

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| Asphalt | | 0 | 8" | |
| Type 2 | | 8" | 3' | |
| Clay w/ Sand | | 3 | 13 | |
| Silty Sand w/ Clay lense | | 13 | 17 | |
| Clay | | 17 | 23 | |
| Silty Sand w/ Clays | | 23 | 37 | |
| Clay | | 37 | 46 | |
| 23 Temp. Dewatering wells in this parcel | | | | |

Date started 9-7-0
Date completed 9-15-0, 19

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|---|---|
| | | |

8. WELL CONSTRUCTION
Depth Drilled 40 Feet Depth Cased 40 Feet

HOLE DIAMETER (BIT SIZE)

| | From | To |
|---|---|---|
| 24 Inches | 0 Feet | 40 Feet |
| Inches | Feet | Feet |
| Inches | Feet | Feet |

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|---|---|---|---|---|
| 6 | PVC | Sch 40 | 0 | 40 |
| | | | | |
| | | | | |

Perforations:
Type perforation Slot
Size perforation .030
From feet to feet
From 10 feet to 40 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☐ Yes ☒ No
Depth of Seal
Placement Method: ☐ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 0 feet to 40 feet

9. WATER LEVEL
Static water level 12 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Griffin Dewatering Contractor
Address 536 E Maitland Contractor
Ontario CA
Nevada contractor's license number issued by the State Contractor's Board 31246
Nevada driller's license number issued by the Division of Water Resources, the on-site driller M1968
Signed By driller performing actual drilling on site or contractor
Date 9-19-0

RECEIVED DWR Received SEP 11 2000 LAS VEGAS OFFICE

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627