

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT
 Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 20315

1. OWNER Contri Coast ADDRESS AT WELL LOCATION On Pecos
 MAILING ADDRESS Lv NV S + N of Sunset
 2. LOCATION 1/4 1/4 Sec. 31 T. 21 N/S E Clark County
 PERMIT NO. DW-1122 Issued by Water Resources Parcel No. 161-3416-001 Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. Driller PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other Bucket

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>Asphalt</u>		<u>0</u>	<u>8"</u>	
<u>Type 2</u>		<u>8"</u>	<u>3'</u>	
<u>Clay w/ sand</u>		<u>3</u>	<u>13</u>	
<u>Silty sand w/ clay lens</u>		<u>13</u>	<u>17</u>	
<u>Clay</u>		<u>17</u>	<u>23</u>	
<u>Silty sand w/ clay</u>		<u>23</u>	<u>37</u>	
<u>Clay</u>		<u>37</u>	<u>46</u>	

23' Temp. Dewatering wells in this parcel


8. WELL CONSTRUCTION
 Depth Drilled 40 Feet Depth Cased 40 Feet
 HOLE DIAMETER (BIT SIZE)
 From 24 Inches To 40 Feet
 From 0 Feet To 40 Feet
 From _____ Inches To _____ Feet
 From _____ Inches To _____ Feet
 CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>4</u>	<u>PUC</u>	<u>5/8</u>	<u>0</u>	<u>40</u>

Perforations:
 Type perforation slot
 Size perforation 0.80
 From _____ feet to _____ feet
 From 10 feet to 40 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout
 Depth of Seal _____
 Placement Method: Pumped Poured
 Gravel Packed: Yes No
 From 0 feet to 40 feet

Date started 9-7-0
 Date completed 9-18-0



7. WELL TEST DATA

TEST METHOD:	TEST METHOD:		
	<input type="checkbox"/> Bailer	<input type="checkbox"/> Pump	<input type="checkbox"/> Air Lift
G.P.M.	Draw Down (Feet Below Static)	Time (Hours)	

9. WATER LEVEL
 Static water level 12 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Griffin Dewatering Contractor
 Address 536 E. Mainland Contractor
Ontario CA
 Nevada contractor's license number issued by the State Contractor's Board. 31246
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller. M1968
 Signed [Signature]
 By driller performing actual drilling on site or contractor
 Date 9-19-0