WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 81301
Permit No.
Basin 61

NOTICE OF INTENT NO. 43617

1. OWNER Barrick Goldstrike Mines PPW-58
MAILING ADDRESS P.O. Box 29
Elko, NV 89803

ADDRESS AT WELL LOCATION Barrick Goldstrike
minesite, north of Carlin, NV.

2. LOCATION NE 1/4 NW 1/4 Sec. 19 T 36N N/S R 50E E Eureka County
PERMIT NO. 55141 Issued by Water Resources | N/A Parcel No. | N/A Subdivision Name

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☐ Deepen ☒ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☒ Municipal/Industrial (Mining) ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☒ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Note: Hole has had the				
top 120' mined off.				
The construction				
information takes this				
into account.				
Well was probed to				
T.D. prior to				
abandoning.				
Abandoned by pumping				
super plug from T.D.				
to 60', placed hole				
plug to 20', and				
cement to surface.				
Quantites Used:				
Super Plug = 262				
cu.ft.				
Hole Plug = 22 cu.ft.				
Cement = 6 cu.ft.				

Date started 5/20/2000 , 19__
Date completed 5/20/2000 , 19__

7. WELL TEST DATA

TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 1010 Feet Depth Cased 1010 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
12.25	Inches	0	Feet	1010	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6.625	17.02	0.250	0	1000

Perforations:
Type perforation Louver
Size perforation 0.375"
From 0 feet to 1000 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☐ Yes ☒ No
Depth of Seal
Placement Method: ☐ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 0 feet to 1010 feet

9. WATER LEVEL
Static water level 124 feet below land surface
Artesian flow N/A G.P.M. N/A P.S.I.
Water temperature N/A °F Quality N/A

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Lang Exploratory Drilling (Contractor)
Address P.O. Box 5279 (Contractor)
Elko, NV 89802-5279
Nevada contractor's license number issued by the State Contractor's Board 0021976
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1410
Signed John Vergetz (By driller performing actual drilling on-site or contractor)
Date 5/23/00

USE ADDITIONAL SHEETS IF NECESSARY

RSL