

OFFICE USE ONLY
 Log No. 81313
 Permit No. _____
 Basin 162

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 18484

1. OWNER Ken Zennor ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS 1281 W. Bluebird Pahump, NV 89048 1281 W. Bluebird
 2. LOCATION NE $\frac{1}{4}$ NE $\frac{1}{4}$ Sec. 20 T. 19 N. 53(E) Nye County
 PERMIT NO. 29-389-11 Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____


6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sand		0	3	3
Sandy Clay		3	12	9
Brown Clay		12	20	8
Gravel		20	24	4
Brown Clay		24	51	27
Gravel	X	51	56	5
Brown Clay	X	56	85	29
Caliche	X	85	88	3
Brown Clay	X	88	160	72

8. WELL CONSTRUCTION
 Depth Drilled 140 Feet Depth Cased 140 Feet
 HOLE DIAMETER (BIT SIZE)
 From 12 Inches To 140 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet
 CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6</u>	<u>-</u>	<u>Sch. 40</u>	<u>0</u>	<u>140</u>

 Perforations:
 Type perforation Saw Cut
 Size perforation 1/8" x 6"
 From _____ feet to _____ feet
 From 120 feet to 140 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 Surface Seal: Yes No Seal Type:
 Depth of Seal 50 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 50 feet to 140 feet



Date started 8-2-00
 Date completed 8-25-00

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>30</u>	<u>8</u>	<u>1/2</u>

9. WATER LEVEL
 Static water level 52 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature Cold °F Quality good

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Harris Water Well Service Contractor
 Address P.O. Box 3392 Contractor
Pahump, NV 89041
 Nevada contractor's license number 0035901
 issued by the State Contractor's Board.
 Nevada driller's license number issued by the 1916
 Division of Water Resources, the on-site driller.
 Signed Larry Jenkins
 By driller performing actual drilling on site or contractor
 Date September 20, 2000