

WHITE-DIVISION OF WATER RESOURCES
CANARY-CLIENT'S COPY
PINK-WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

OFFICE USE ONLY

Log No. 81315
Permit No. _____
Basin 61

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 43621

1. OWNER BARRICK GOLDSTRIKE MINES ADDRESS AT WELL LOCATION BARRICK GOLDSTRIKE MINESITE, NORTH OF CARLIN, NV.
MAILING ADDRESS P.O. BOX 29
ELKO, NV 89803

2. LOCATION NE 1/4 SE 1/4 Sec. 19 T. 36 N. R. 50 E. EUREKA County
PERMIT NO. 55140 Issued by Water Resources Parcel No. N/A Subdivision Name N/A

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other.....

4. PROPOSED USE
 Domestic Municipal Industrial Irrigation Test Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other.....

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thick-ness |
|---|--------------|------|-----|------------|
| *NOTE: UPPER 345' OF THIS WELL HAS BEEN MINED OFF. THE CASING THAT REMAINS IS KINKED AT 58'. THE CONSTRUCTION DATA REFLECT THE ORIGINAL CONSTRUCTION. THIS WELL WILL BE BENEATH THE ANTICIPATED PIT LAKE. | | | | |
| FILL MATERIAL WAS DRILLED OUT FROM 290' TO 755' PRIOR TO ABANDONING. | | | | |
| ABANDONED BY PUMPING ABANTONITE VIA TREMMIE FROM T.D TO 660', HOLE PLUG TO 20', AND CEMENT TO SURFACE. | | | | |
| QUANTITIES USED: | | | | |
| CEMENT: 28 CU.FT. | | 0 | 20 | 20 |
| HOLE PLUG: 820 CU.FT. | | 20 | 660 | 640 |
| ABANTONITE: 301 CU.FT. | | 660 | 755 | 95 |

8. WELL CONSTRUCTION
Depth Drilled 1110 Feet Depth Cased 1100 Feet

HOLE DIAMETER (BIT SIZE)
From To
17.5 Inches 0 Feet 1110 Feet
Inches Feet Feet
Inches Feet Feet

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|--------------------|---------------------|-------------------------|-------------|-----------|
| 12.75 | 33.38 | 0.250 | +3 | 1100 |

Perforations:
Type perforation LOUVER
Size perforation 0.125"
From 140 feet to 180 feet
From 260 feet to 300 feet
From 380 feet to 420 feet
From 500 feet to 1100 feet

Surface Seal: Yes No Seal Type:
Depth of Seal 100' Neat Cement
Placement Method: Pumped Cement Grout
 Poured Concrete Grout

Gravel Packed: Yes No
From 100 feet to 1110 feet

9. WATER LEVEL
Static water level 660 feet below land surface
Artesian flow N/A G.P.M. _____ P.S.I. _____
Water temperature _____ °F Quality _____

Date started JULY 22, 2000
Date completed JULY 24, 2000

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|--------|-------------------------------|--------------|
| | | |
| | | |
| | | |
| | | |
| | | |
| | | |

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name LANG EXPLORATORY DRILLING Contractor
Address P.O. BOX 5279 Contractor
ELKO, NV 89802-5279
Nevada contractor's license number issued by the State Contractor's Board 0021976
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1888
Signed David Doriot
By driller performing actual drilling on site or contractor
Date AUGUST 1, 2000