

STATE OF NEVADA
 DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
 Log No. 81325
 Permit No. 61
 Basin 61
 NOTICE OF INTENT NO. 43623

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

Please complete this form in its entirety in
 accordance with NRS 534.170 and NAC 534.340

1. OWNER Barrick Goldstrike Mines PZ99-16 # ADDRESS AT WELL LOCATION Barrick Goldstrike
 MAILING ADDRESS P. O. Box 29 Minesite, North of Carlin, NV.
Elko, NV 89803

2. LOCATION NW 1/4 SE 1/4 Sec 19 T 36N N/S R 50E E Eureka County
 PERMIT NO. N/A Issued by Water Resources | N/A Parcel No. | N/A Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition Deepen Abandon Other

4. PROPOSED USE
 Domestic Municipal/Industrial Irrigation Monitor Test Stock

5. WELL TYPE
 Cable Air Rotary Other RVC

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Both tubes abandoned by pumping neat cement from T.D. to surface.				
Quantities Used:				
#1: 9.2 cu.ft.				
#2: 5.8 cu.ft.				
Original Construction:				
Cement		0	20	20
Hole Plug		20	105	85
Gravel		105	140	35
Hole Plug		140	148	8
Cement		148	155	7
Gole Plug		155	160	5
Gravel		160	200	40
<i>Plugging of dual completion</i>				

8. WELL CONSTRUCTION

Depth Drilled 200 Feet Depth Cased 197 Feet

HOLE DIAMETER (BIT SIZE)

	From	To	Feet	Feet
<u>14.75</u> Inches	<u>0</u>	<u>20</u>		
<u>7.875</u> Inches	<u>20</u>	<u>200</u>		

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>10.75</u>	<u>28.04</u>	<u>0.250</u>	<u>0</u>	<u>20</u>
<u>1: 2.375</u>	<u>3.65</u>	<u>0.154</u>	<u>+1</u>	<u>197</u>
<u>2: 2.375</u>	<u>3.65</u>	<u>0.154</u>	<u>+1</u>	<u>135</u>

Perforations:

Type perforation Mill Slot
 Size perforation 0.125" X 3"

From	To	Feet	Feet
<u>1: 177</u>	<u>197</u>		
<u>2: 115</u>	<u>135</u>		

Surface Seal: Yes No Seal Type: Neat Cement
 Depth of Seal 20' Cement Grout
 Placement Method: Pumped Concrete Grout
 Poured

Gravel Packed: Yes No
 From _____ feet to _____ feet

9. WATER LEVEL
 Static water level Both tubes dry feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

7. WELL TEST DATA

TEST METHOD:	Bailer	Pump	Air Lift
G.P.M.	Draw Down (Foot Below Static)	Time (Hours)	

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Lang Exploratory Drilling Contractor
 Address P.O. Box 5279 Contractor
Elko, NV 89802-5279
 Nevada contractor's license number issued by the State Contractor's Board 0021976
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2115

Signed Dustin Wilcox
 By driller performing actual drilling on-site or contractor
 Date 6/10/2000