WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

# WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 81428
Permit No.
Basin 212

NOTICE OF INTENT NO. 20685

1. OWNER City of Las Vegas Water
MAILING ADDRESS 3617 N. 5th Street
N. Las Vegas, NV 89032

ADDRESS AT WELL LOCATION Las Vegas Valley Water District
6005 E. Vegas Valley Dr.
Las Vegas, NV 89122

2. LOCATION S ¼ SW ¼ Sec. 10 T. 21 N/S R. 62 E. Clark County
PERMIT NO. DW1113 (Issued by Water Resources) 161-10-401-003 (Parcel No.) Subdivision Name Well 14

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☐ Deepen ☒ Abandon ☐ Other

4. Dewater PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☒ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| Abandon 14-30' Dewater wells | | | | |
| No access for drilling rig. Pulled casings with crane. Cement trimmie 1 1/2 yards sand cement slurry each. | | | | |

Date started 10/3 2000
Date completed 10/5 2000

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|---|---|
| | | |

8. WELL CONSTRUCTION
Depth Drilled 30' Feet Depth Cased 30' Feet

HOLE DIAMETER (BIT SIZE)

| | From | To |
|---|---|---|
| 24" Inches | 0 Feet | 30' Feet |
| Inches | Feet | Feet |
| Inches | Feet | Feet |

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|---|---|---|---|---|
| 14" | 36.71 | 1.250 | 0 | 30' |
| | | | | |
| | | | | |

Perforations:
Type perforation Machine
Size perforation 1/4" x 2 1/2" x 3 rows @ 13
From 10' feet to 30' feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☐ Yes ☐ No
Depth of Seal
Placement Method: ☐ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☐ Concrete Grout
Gravel Packed: ☐ Yes ☐ No
From feet to feet

9. WATER LEVEL
Static water level feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name ALLEN DRILLING INC. (Contractor)
Address 4847 S. VALLEY VIEW (Contractor)
LAS VEGAS, NV 89103
Nevada contractor's license number issued by the State Contractor's Board 18917
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1301
Signed (By driller performing actual drilling on site or contractor)
Date 10-10-00

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627