

OFFICE USE ONLY
 Log No. 81448
 Permit No. _____
 Basin. 212

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT No. 19185

1. OWNER Larry Miller of Nevada Ready Mix ADDRESS AT WELL LOCATION 601 W. BONANZA RD
 MAILING ADDRESS 601 W. BONANZA RD
Las Vegas NV 89106

2. LOCATION SW 1/4 SW 1/4 Sec. 27 T. 20 N. 61 E. CLARK County
 PERMIT NO. WA 139-27-401-002 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other Auger

6. LITHOLOGIC LOG RMW-2c

Material	Water Strata	From	To	Thick-ness
<u>Fill - Sandy Gravel</u>		<u>0</u>	<u>6</u>	
<u>SILTY CLAY</u>		<u>6</u>	<u>10.5</u>	
<u>CALICHE</u>		<u>10.5</u>	<u>14</u>	
<u>Clayey Gravel</u>	<u>Y</u>	<u>14</u>	<u>16.5</u>	
<u>SANDY CLAY</u>	<u>Y</u>	<u>16.5</u>	<u>18.5</u>	
<u>CLAYEY SAND</u>	<u>Y</u>	<u>18.5</u>	<u>21</u>	
<u>SANDY CLAY</u>	<u>Y</u>	<u>21</u>	<u>25</u>	

8. WELL CONSTRUCTION
 Depth Drilled 25 Feet Depth Cased 22 Feet

HOLE DIAMETER (BIT SIZE)
 From 0 To 25
8.5 Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>4</u>	<u>PVC</u>	<u>sch 40</u>	<u>0</u>	<u>22</u>

Perforations:
 Type perforation slotted screen
 Size perforation .020 inch
 From 7 feet to 22 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 6 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout

Gravel Packed: Yes No
 From 6 feet to 25 feet

9. WATER LEVEL
 Static water level 14 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

Date started Oct. 10 2000
 Date completed Oct 10 2000

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
/		

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.


Name Tim Allen of Terracon Contractor
 Address 4343 S. Polaris Ave Contractor
Las Vegas NV 89103

Nevada contractor's license number issued by the State Contractor's Board _____
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller M2155


Signed Tim Allen
 By driller performing actual drilling on site or contractor
 Date 10/20/00



BONANZA ROAD



SITE ADDRESS: 601 W. BONANZA ROAD



ALL LOCATIONS APPROXIMATE

EXPLANATION:
 MW-3 - MONITORING WELL AND NUMBER

CLIENT:	NEVADA READY MIX	Terracon		SITE DIAGRAM	
PROJECT:	601 WEST BONANZA ROAD				
		PROJECT NO.:	64987298	FIGURE:	1