WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

# WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 81455
Permit No.
Basin 163

NOTICE OF INTENT NO. 20135

1. OWNER JOHN & BARBARA KOLPACK
MAILING ADDRESS
ADDRESS AT WELL LOCATION: RANCHO EWING RD. & LORENZO RD. SANDY VALLEY

2. LOCATION SE¼/NE ¼ NW¼/SE¼ Sec. 16 T. 25 N/S R. 57 E. CLARK County
PERMIT NO. Issued by Water Resources | 219-16-701-007-01 Parcel No. | Subdivision Name

3. WORK PERFORMED
☑ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☑ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☑ Rotary ☐ RVC
☑ Air ☐ Other

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| SANDY LOAM | | 0 | 10 | 10 |
| CLAY | | 10 | 42 | 32 |
| CLAY + GRAVEL | | 42 | 52 | 10 |
| CALICHIE | W.B | 52 | 59 | 7 |
| CLAY + GRAVEL | | 59 | 81 | 22 |
| GRAVEL + SAND | W.B | 81 | 91 | 10 |
| CEMENTED SAND + GRAVEL | | 91 | 102 | 11 |
| ROCK + GRAVEL | W.B | 102 | 120 | 18 |

DCNR/DWR Received OCT 19 2000 LAS VEGAS OFFICE

Date started 9-18 2000
Date completed 9-29 2000

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|---|---|
| | | |

8. WELL CONSTRUCTION
Depth Drilled 120 Feet Depth Cased 120 Feet

HOLE DIAMETER (BIT SIZE)

| | | From | To |
|---|---|---|---|
| 10 5/8 Inches | 0 Feet | 120 Feet | |
| Inches | Feet | Feet | |
| Inches | Feet | Feet | |

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|---|---|---|---|---|
| 6 5/8 | 4.33 | .316 | 0 | 120 |
| | | | | |

Perforations:
Type perforation SAW CUT
Size perforation 1/8 INCH BY 3 INCH
From 120 feet to 100 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 50 FT.
Placement Method: ☑ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☑ Cement Grout ☐ Concrete Grout

Gravel Packed: ☑ Yes ☐ No
From 120 feet to 50 feet

9. WATER LEVEL
Static water level 37 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature COOL °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name BUDGET DRILLING CO. Contractor
Address P.O. BOX 3505 PAHRUMP NV. 89041 Contractor
Nevada contractor's license number issued by the State Contractor's Board 40020
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1578
Signed By driller performing actual drilling on site or contractor
Date 10-6-2000

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627