WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 81461
Permit No.
Basin 212

NOTICE OF INTENT NO. 21372

1. OWNER Maryland Square Shopping Center LLC
MAILING ADDRESS 252 Convention Center Drive
Las Vegas, NV 89109

ADDRESS AT WELL LOCATION 3528 Maryland Parkway,
Las Vegas, Nevada

2. LOCATION SW 1/4 SW 1/4 Sec. 14 T 21S N/S R 61E E Clark County
PERMIT NO. (Issued by Water Resources) 162-14-213-002 (Parcel No.) MW-6 (Subdivision Name)

3. **WORK PERFORMED**
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. **PROPOSED USE**
[ ] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [X] Monitor [ ] Stock

5. **WELL TYPE**
[ ] Cable [X] Rotary [ ] RVC
[ ] Air [ ] Other

6. **LITHOLOGIC LOG**

Material	Water Strata	From	To	Thickness
Brown silty CLAY		0	18	18
Caliche layer		18	20	2
Brown silty CLAY		20	32	12

Date started 10/3/2000, 19__
Date completed 10/3/2000, 19__

7. **WELL TEST DATA**
TEST METHOD: [ ] Bailer [ ] Pump [ ] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. **WELL CONSTRUCTION**
Depth Drilled 32 Feet Depth Cased 30 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
5	Inches	0	Feet	32	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2.375	0.64	0.218	0	25

Perforations:
Type perforation factory slot PVC
Size perforation 0.020
From 10 feet to 30 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 0-2',2-4 bentonite
Placement Method: [ ] Pumped [X] Poured
Seal Type: [ ] Neat Cement [X] Cement Grout [ ] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 4 feet to 30 feet

9. **WATER LEVEL**
Static water level 17.41 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. **DRILLER'S CERTIFICATION**
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Don Wilson c/o Converse Consultants (Contractor)
Address 731 Pilot Road, Suite H (Contractor)
Las Vegas, NV 89119
Nevada contractor's license number issued by the State Contractor's Board 48947
Nevada driller's license number issued by the Division of Water Resources, the on-site driller M-1589
Signed (By driller performing actual drilling on-site or contractor)
Date 10/16/2000

USE ADDITIONAL SHEETS IF NECESSARY



DCNR/DWR
Received
OCT 23 2000
LAS VEGAS OFFICE

LOCATION OF SUBSURFACE EXPLORATIONS

HERMAN KISHNER TRUST
3661 South Maryland Parkway
Las Vegas, Nevada

Scale: N.T.S.	File No.: 36701002
Date: 10/10/00	Project No.: 00-43367-01
Drafted By: GLE	Drawing No.: 2
Checked By: ALM	
Approved By: am	

CONVERSE CONSULTANTS

Over 50 Years of Dedication in Engineering and Environmental Sciences