WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 81464
Permit No.
Basin 162

NOTICE OF INTENT NO. 19701

1. OWNER Mike Fortin
MAILING ADDRESS 3851 S. Mallard Ave
Pahrump, Nevada 89048

ADDRESS AT WELL LOCATION 3851 S. Mallard Ave.
Pahrump, Nevada 89048

2. LOCATION NE ¼ SE ¼ Sec. 36 T. 20 N/S R. 53 E. Nye County

PERMIT NO. (Issued by Water Resources) | Parcel No. 41-134-03 | Subdivision Name Calvada Valley Unit 2

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☒ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
silt		0'	20'	20'
white Clay		20'	30'	10'
caliche		30'	35'	5'
white clay		35'	50'	15'
caliche		50'	60	10'
brown clay		60'	95'	35'
caliche		95'	100'	5'
brown clay		100'	120'	20'
caliche		120'	125'	5'
brown clay		125'	150'	25'
caliche		150'	155'	5'
brown clay		155'	160'	5'

DCNR/DWR Received OCT 25 2000 LAS VEGAS OFFICE

Date started September 18, 2000
Date completed September 22, 2000

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 160 Feet Depth Cased 160 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
12 Inches	0 Feet	160 Feet	
Inches	Feet	Feet	
Inches	Feet	Feet	

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6.625	4.33	.316	0'	160'

Perforations:
Type perforation Saw Cut
Size perforation 1/8" x 3"
From 120 feet to 160 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50'
Placement Method: ☐ Pumped ☒ Poured

Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 160 feet

9. WATER LEVEL
Static water level 70' feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name LaRue Construction Co. (Contractor)
Address 4191 S. Jackie St. (Contractor)
Pahrump, Nevada
Nevada contractor's license number issued by the State Contractor's Board 0049225
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2116
Signed Forest LaRue (By driller performing actual drilling on site or contractor)
Date September 26, 2000

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627