

OFFICE USE ONLY
Log No. 81471
Permit No. _____
Basin. 212

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 21997

1. OWNER Audrey S. Clark
MAILING ADDRESS 6122 Grand Teton
Las Vegas, NV 89131
ADDRESS AT WELL LOCATION 6122 Grand Teton
2. LOCATION SE 1/4 SE 1/4 Sec 11 T 19 N/S R 60 E Clark County
PERMIT NO. 125-11-806-015
Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other
4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
5. WELL TYPE
 Cable Rotary RVC
 Air Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
original 340' drilled by others				
Clay		340	445	105
Sand & gravel		445	455	10
Brown clay		455	496	41
Clay, sand & gravel	x	496	518	22
Brown clay		518	562	44
Brown loose sand	x	562	604	42
Pink clay		604	624	20
Sand & gravel, pink clay		624	645	21
Clay w/gravel stringers		645	700	55

8. WELL CONSTRUCTION
Depth Drilled 700 Feet Depth Cased 700 Feet
HOLE DIAMETER (BIT SIZE)
7 7/8 Inches 340 Feet 780 Feet
Inches Feet Feet
Inches Feet Feet
Inches Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6"		.188	340	700

Perforations:
Type perforation Mill slot
Size perforation 2" x 1/4"
From 340 feet to 360 feet
From 400 feet to 420 feet
From 440 feet to 460 feet
From 500 feet to 520 feet
From 560 feet to 600 feet
From 620 feet to 640 feet

Surface Seal: Yes No Seal Type:
 Neat Cement
Depth of Seal _____ Cement Grout
Placement Method: Pumped Concrete Grout
 Poured
Gravel Packed: Yes No
From _____ feet to _____ feet

9. WATER LEVEL
Static water level _____ feet below land surface
Artesian flow _____ G.P.M. _____ P.S.I.
Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Thompson Drilling Co., Inc.
Address 7227 Hauck Street
Las Vegas, NV 89118
Nevada contractor's license number 4286A
issued by the State Contractor's Board
Nevada driller's license number issued by the 2120
Division of Water Resources, the on-site driller
Signed Richard Thompson
By driller performing actual drilling on site or contractor
Date 10/27/00

Date started 10/16/00, 19____
Date completed 10/21/00, 19____

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

