WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 81472
Permit No.
Basin 212

NOTICE OF INTENT NO. 21829

1. OWNER Jodie Chimielewski
MAILING ADDRESS P.O Box 97251
Las Vegas Nev 89193
ADDRESS AT WELL LOCATION 5615 W. Shelborn

2. LOCATION SW ¼ NE ¼ Sec. 13 T. 22 N/S R. 60 E. Clark County
PERMIT NO. (Issued by Water Resources) 176 (Parcel No.) 13 601 001 (Subdivision Name)

3. WORK PERFORMED
☐ New Well ☑ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☑ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☑ Rotary ☐ RVC
☑ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sand Gravel + Boulders		0	315	
Red + Pink Sand Stone		315	400	
Sand Gravel Boulders		35	400	505

Total Amount of Cement grout Used 5 Yards For Seal & Plugging of old well

DCNR/DWR Received OCT 30 2000 LAS VEGAS OFFICE

Date started 10-18-2000, 19
Date completed 10-25-2000, 19

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☑ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
35		30 min

8. WELL CONSTRUCTION
Depth Drilled 505 Feet Depth Cased 485 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10" Inches	8 Feet	505 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	Sch 40	F 480	+1	485
8 5/8		188	+2	5

Perforations:
Type perforation Saw
Size perforation 1/8 X 6 X 3
From 420 feet to 485 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 50
Placement Method: ☐ Pumped ☑ Poured
Seal Type: ☐ Neat Cement ☑ Cement Grout ☐ Concrete Grout
Gravel Packed: ☑ Yes ☐ No
From 50 feet to 485 feet

9. WATER LEVEL
Static water level 329 feet below land surface
Artesian flow — G.P.M. — P.S.I.
Water temperature °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name (Contractor) Redding Drilling
Address (Contractor) 3955 Blue Diamond Rd #4
Las Vegas Nev. 89139
Nevada contractor's license number issued by the State Contractor's Board 38155
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1798
Signed (By driller performing actual drilling on site or contractor)
Date 10-26-2000

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627