WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 81476
Permit No. 51635
Basin 212

NOTICE OF INTENT NO. 21618

1. OWNER MEL DAINES
MAILING ADDRESS
ADDRESS AT WELL LOCATION MT. CHARLESTON LODGE

2. LOCATION NE ¼ SW ¼ Sec. 28 T. 19 N/S R. 57 E. CLARK County
PERMIT NO. 51635 (Issued by Water Resources) | 128-28-304-001 (Parcel No.) | Subdivision Name

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☒ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☒ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☒ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
FRACTURED LIMESTONE		460	490	30
LIMESTONE		490	520	30
FRACTURED LIMESTONE		520	560	40
LIMESTONE		560	890	330
FRACTURED LIMESTONE	X	890	900	10

Date started 10/13/00 XX
Date completed 10/20/00 XX

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 900 Feet Depth Cased 900 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
7 7/8 Inches	460 Feet	900 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.9	.188	380	900

Perforations:
Type perforation FACTORY
Size perforation 1/8 X 3 6 ROWS
From 760 feet to 820 feet
From 880 feet to 900 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☐ Yes ☐ No
Depth of Seal
Placement Method: ☐ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☐ Concrete Grout
Gravel Packed: ☐ Yes ☐ No
From feet to feet

9. WATER LEVEL
Static water level 285 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name WATER WELL SERVICES (Contractor)
Address 6475 GARY AVE. (Contractor)
LAS VEGAS, NV 89139
Nevada contractor's license number issued by the State Contractor's Board 22311B
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1594
Signed (By driller performing actual drilling on site or contractor)
Date 10/27/00

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627

WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 81476
Permit No. 44289
Basin 212

NOTICE OF INTENT NO. 21618

OWNER MT. CHARLESTON WATER
MAILING ADDRESS

ADDRESS AT WELL LOCATION MT. CHARLESTON LODGE

2. LOCATION: NE ¼ SW ¼ Sec. 28 T. 19 N/S R. 57 E. CLARK County
PERMIT NO. 44289 (Issued by Water Resources) | 128-28-304-001 (Parcel No.) | Subdivision Name

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☒ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☒ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☒ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
FRACTURED LIMESTONE		460	490	30
LIMESTONE		490	520	30
FRACTURED LIMESTONE		520	560	40
LIMESTONE		560	890	330
FRACTURED LIMESTONE	X	890	900	10

REVISED

Date started 10/13/00 XX
Date completed 10/20/00 XX

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 900 Feet Depth Cased 900 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
7 7/8 Inches	460 Feet	900 Feet	
Inches	Feet	Feet	
Inches	Feet	Feet	

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.9	.188	380	900

Perforations:
Type perforation FACTORY
Size perforation 1/8 X 3 6 ROWS
From 760 feet to 820 feet
From 880 feet to 900 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☐ Yes ☐ No
Depth of Seal
Placement Method: ☐ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☐ Concrete Grout
Gravel Packed: ☐ Yes ☐ No
From feet to feet

9. WATER LEVEL
Static water level 285 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name WATER WELL SERVICES (Contractor)
Address 6475 GARY AVE. (Contractor)
LAS VEGAS, NV 89139
Nevada contractor's license number issued by the State Contractor's Board 22311B
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1594
Signed (By driller performing actual drilling on site or contractor)
Date 10/27/00

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627