

PRINT OR TYPE ONLY  
DO NOT WRITE ON BACK

**WELL DRILLER'S REPORT**  
Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 19108

1. OWNER Bill Myers ADDRESS AT WELL LOCATION \_\_\_\_\_  
MAILING ADDRESS 4551 W. Danner St. Pahrump, Nevada 89048 \_\_\_\_\_  
2. LOCATION SW 1/4 NE 1/4 Sec 14 T 20 N 32 E Nye \_\_\_\_\_ County  
PERMIT NO. 41-481-02 Golden Spring Ranch Unit 3 \_\_\_\_\_  
Issued by Water Resources Parcel No. \_\_\_\_\_ Subdivision Name \_\_\_\_\_

3. WORK PERFORMED  New Well  Replace  Recondition  Deepen  Abandon  Other \_\_\_\_\_  
4. PROPOSED USE  Domestic  Irrigation  Test  Municipal/Industrial  Monitor  Stock  
5. WELL TYPE  Cable  Rotary  RVC  Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
<u>brown clay</u>		<u>0</u>	<u>5'</u>	<u>5'</u>
<u>white clay</u>		<u>5'</u>	<u>25'</u>	<u>20'</u>
<u>caliche</u>		<u>25'</u>	<u>30'</u>	<u>5'</u>
<u>green clay</u>		<u>30'</u>	<u>45'</u>	<u>15'</u>
<u>white clay</u>		<u>45'</u>	<u>60'</u>	<u>15'</u>
<u>green clay</u>		<u>60'</u>	<u>100'</u>	<u>40'</u>
<u>white clay</u>		<u>100'</u>	<u>110'</u>	<u>10'</u>
<u>green clay</u>		<u>110'</u>	<u>140'</u>	<u>30'</u>

8. WELL CONSTRUCTION  
Depth Drilled 140 Feet Depth Cased 140 Feet  
HOLE DIAMETER (BIT SIZE)  
From 12 Inches To 0 Feet 140 Feet  
Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6.625</u>	<u>4.33</u>	<u>.316</u>	<u>0</u>	<u>140</u>

Perforations:  
Type perforation Saw cut  
Size perforation 1/8" x 3"  
From 100 feet to 140 feet  
From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  Neat Cement  Cement Grout  Concrete Grout  
Depth of Seal 50'  
Placement Method:  Pumped  Poured  
Gravel Packed:  Yes  No  
From 50 feet to 140' feet

9. WATER LEVEL  
Static water level 50 feet below land surface  
Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ S.P.S.  
Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_

10. DRILLER'S CERTIFICATION  
This well was drilled under my supervision and the report is true to the best of my knowledge.  
Name Larue Construction Co.  
Address 4191 S. Jackie St. Pahrump, Nevada  
Nevada contractor's license number issued by the State Contractor's Board 0049225  
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2116  
Signed Forest Larue  
By driller performing actual drilling on site or contractor  
Date November 14, 2000 11/14/2000

Date started November 6, 2000  
Date completed November 13, 2000

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			

