WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 81527
Permit No.
Basin 162

NOTICE OF INTENT NO. 19104

1. OWNER Charles Holloway
MAILING ADDRESS 821 W. Amarillo Ave
Pahrump, Nevada 89048

ADDRESS AT WELL LOCATION 821 W. Amarillo Ave
Pahrump, Nevada 89048

2. LOCATION NW ¼ SW ¼ Sec. 28 T. 20 N/S R. 53 E. Nye County
PERMIT NO. (Issued by Water Resources) Parcel No. 40-262-11 Subdivision Name Caluada Valley Units

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☒ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
brown clay		0'	5'	5'
white clay		5'	30'	25'
caliche		30'	35'	5'
white clay		35'	50'	15'
caliche		50'	60'	10'
brown clay		60'	100'	40'
caliche		100'	105'	5'
brown clay		105'	120'	15'
white clay		120'	130'	10'
brown clay		130'	140	10'

Date started October 19, 2000
Date completed October 23, 2000

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 140 Feet Depth Cased 140 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
12 Inches		0 Feet	140 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
4.625	4.33	.316	0'	140'

Perforations:
Type perforation Saw cut
Size perforation 1/8" X 3"
From 100 feet to 140 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☐ Pumped ☒ Poured

Seal Type:
☐ Neat Cement
☐ Cement Grout
☒ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 140' feet

9. WATER LEVEL
Static water level 55 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name LaRue Construction Co. (Contractor)
Address 4191 S. Jackie St. (Contractor)
Pahrump, Nevada
Nevada contractor's license number issued by the State Contractor's Board 0049225
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2116
Signed Forest LaRue (By driller performing actual drilling on site or contractor)
Date November 13, 2000

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627