WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 81549
Permit No.
Basin 212

NOTICE OF INTENT NO. 21367

1. OWNER Amec Earth & Environmental
MAILING ADDRESS 4205 West Tompkins Avenue, Suite 5
Las Vegas, NV 89103

ADDRESS AT WELL LOCATION 707 South 1st Street

LOCATION NW 1/4 SW 1/4 Sec. 34 T 20S N/S R 61E E Clark County

PERMIT NO. (Issued by Water Resources) | Parcel No. 139-34-310-040 | Subdivision Name

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[ ] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [X] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[ ] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Silty Lean Clay		0	11	11
Caliche		11	13.5	2.5
Silty Lean Clay		13.5		
w/caliche nodules			18.5	5
Caliche		18.5	20	1.5
Lean Silty Clay, brown		20	25	5

DCNR/DWR Received NOV 27 2000 LAS VEGAS OFFICE

Date started 8/30/00, 19__
Date completed 8/30/00, 19__

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [ ] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 25 Feet Depth Cased 20 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
6 Inches		0 Feet	25 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2.375	0.64	0.154	0	20

Perforations:
Type perforation Factory Slotted PVC
Size perforation 0.020 Inches
From 10 feet to 20 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 0-2', 2-5' Bentonite
Placement Method: [ ] Pumped [X] Poured
Seal Type: [ ] Neat Cement [X] Cement Grout [ ] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 5 feet to 23 feet

9. WATER LEVEL
Static water level 11.3 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Don Wilson c/o Converse Consultants (Contractor)
Address 731 Pilot Road, Suite H (Contractor)
Las Vegas, NV 89119
Nevada contractor's license number issued by the State Contractor's Board 48947
Nevada driller's license number issued by the Division of Water Resources, the on-site driller M-1589
Signed Don Wilson (By driller performing actual drilling on-site or contractor)
Date 11/10/00

USE ADDITIONAL SHEETS IF NECESSARY