WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 81562
Permit No.
Basin 212

NOTICE OF INTENT NO. 20317

1. OWNER Centri Cont.
MAILING ADDRESS LV NV
ADDRESS AT WELL LOCATION East Cdo Ave to Lamb Blvd

2. LOCATION ____ ¼ ____ ¼ Sec 5 T 21 N/S R 62 E ____ County
PERMIT NO. DW 1116 (Issued by Water Resources) 161-05-161-008 (Parcel No.) ____ (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other ____

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☒ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☒ Other Rocket

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Clay & Sand X		0	8	
Dirty Sand	10	8	15	
Sand/Clay X		15	20	
Conglomerate Sand Mix		20	25	
Sand/Gravel Mix		25	35	

DRILL 9 WELLS with MATERIAL same on 70' Centers at Depth 35', on this Parcel.

DCNR/DWR Received DEC 6 2000 LAS VEGAS OFFICE

Date started 12-4 —, 19 00
Date completed 12-5 —, 19 00

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 35 Feet Depth Cased 35 Feet

HOLE DIAMETER (BIT SIZE)

Inches	From Feet	To Feet
24	0	35

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8	PVC	Sch 40	0	35

Perforations:
Type perforation Slot
Size perforation .030
From ____ feet to ____ feet
From 10 feet to 35 feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet

Surface Seal: ☐ Yes ☒ No
Depth of Seal ____
Placement Method: ☐ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 0 feet to 35 feet

9. WATER LEVEL
Static water level 10 feet below land surface
Artesian flow ____ G.P.M. ____ P.S.I.
Water temperature ____ °F Quality ____

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name GD
Contractor
Address 536 E Wathud
Contractor
Onton: CA
Nevada contractor's license number issued by the State Contractor's Board 31246
Nevada driller's license number issued by the Division of Water Resources, the on-site driller M1966
Signed ____
By driller performing actual drilling on site or contractor
Date 12-8

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627