WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 81573
Permit No.
Basin 162

NOTICE OF INTENT NO. 19509

1. OWNER Robert Flaherty
MAILING ADDRESS 1410 W. Hurricane Pahrump
ADDRESS AT WELL LOCATION 1410 W. Hurricane Pahrump Nevada 89048

2. LOCATION SE ¼ SE ¼ Sec. 29 T. 20 N/S R. 53 E/W Nye County
PERMIT NO. Issued by Water Resources | Parcel No. 40-383-17 | Subdivision Name

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[X] Cable [ ] Rotary [ ] RVC
[ ] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Grey Clay		0	7	7
Brown Clay		7	24	17
Calichia	X	24	52	28
light brown Clay	X	52	60	8
Decomposed Calichia	X	60	85	25
Sandy gravel	X	85	89	4
Grey Clay	X	89	130	41
light brown Clay	X	130	132	2
brown Clay	X	132	140	8

DCNR/DWR Received DEC 7 2000 LAS VEGAS OFFICE

Date started 10-19-00, 19
Date completed 10-23-00, 19

7. WELL TEST DATA
TEST METHOD: [X] Bailer [ ] Pump [ ] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
30	3	1/0

8. WELL CONSTRUCTION
Depth Drilled 140 Feet Depth Cased 140 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
12 Inches	0 Feet	140 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8	17	.188	0	140

Perforations:
Type perforation Saw
Size perforation 1/8 x 6"
From 120 feet to 140 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50
Placement Method: [ ] Pumped [X] Poured
Seal Type: [ ] Neat Cement [ ] Cement Grout [X] Concrete Grout
Gravel Packed: [X] Yes [ ] No
From 50 feet to 140 feet

9. WATER LEVEL
Static water level 51 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature Cold °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Parrish Water Well Service (Contractor)
Address P.O. Box 3392 (Contractor)
Pahrump, NV 89041
Nevada contractor's license number issued by the State Contractor's Board 0035901
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1916
Signed Lara Jenkins (By driller performing actual drilling on site or contractor)
Date November 26, 2000

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (OI-627)