

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

1. OWNER David Neighman ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS _____
3110 W. Prospector Pahrump 3110 W. Prospector
 2. LOCATION SE 1/4 SE 1/4 Sect 13 T 20 N 52 E County _____
 PERMIT NO. _____ Parcel No. 28-683-02 Subdivision Name Charleston Park Unit 1

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Sandy Soil		0	7	7
Grey Clay		7	24	17
Caliche		24	52	28
Light brown Clay	X	52	60	8
Brown Clay	X	60	85	25
Sandy Soil	X	85	89	4
Caliche	X	89	130	41
Brown Clay	X	130	132	2
Light brown Clay	X	132	140	8

8. WELL CONSTRUCTION
 Depth Drilled 140 Feet Depth Cased 140 Feet
 HOLE DIAMETER (BIT SIZE)
 From 0 To 140
12 Inches 0 Feet 140 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6</u>	<u>-</u>	<u>Sch-40</u>	<u>0</u>	<u>140</u>

Perforations:
 Type perforation Saw Cut
 Size perforation 1/8" x 6"
 From _____ feet to _____ feet
 From 120 feet to 140 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout
 Depth of Seal 50
 Placement Method: Pumped Poured
 Gravel Packed: Yes No
 From 50 feet to 140 feet

9. WATER LEVEL
 Static water level 53 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature Cold °F Quality Good

Date started 9-15-00, 19____
 Date completed 9-20-00, 19____

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input checked="" type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift	<u>30</u>	<u>6</u>	<u>1/2</u>

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Gene Maysa Contractor
 Address _____ Contractor
Pahrump, NV 89041
 Nevada contractor's license number 1916 issued by the State Contractor's Board
 Nevada driller's license number issued by the Division of Water Resources _____ on-site driller
 Signed Gene Maysa By driller performing actual drilling on site or contractor
 Date 10/3/2000

