

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 19510

1. OWNER West Sandra Miller ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS _____ 3150 S. Woodchips Pahrump
 2. LOCATION NE 1/4 NW 1/4 Sec. 31 T. 20 N/S R. 53 @ Tye County _____
 PERMIT NO. _____ Parcel No. 30-491-03 Subdivision Name _____
 Issued by Water Resources _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____


6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Brown Clay		0	12	12
Grey Clay		12	46	
Caliche	X	46	68	
Sandy Soil	X	68	89	
Light Brown Clay	X	89	101	
Grey Clay	X	101	120	
Brown Clay	X	120	140	

8. WELL CONSTRUCTION
 Depth Drilled 140 Feet Depth Cased 140 Feet
 HOLE DIAMETER (BIT SIZE)
 From 12 Inches To 140 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet
 CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
12	170	.188	0	140

Perforations:
 Type perforation Factory
 Size perforation 3x4x4
 From _____ feet to _____ feet
 From 120 feet to 140 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 Surface Seal: Yes No Seal Type:
 Depth of Seal 50 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 50 feet to 140 feet



9. WATER LEVEL
 Static water level 53 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.F.
 Water temperature Cold °F Quality good

Date started 10-22-00, 19____
 Date completed 10-28-00, 19____

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
30	3	1/2

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Parry Water Well Service Contractor
 Address P.O. Box 3390 Contractor
Pahrump, NV 89001
 Nevada contractor's license number issued by the State Contractor's Board 0035901
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1914
 Signed Parry Jenkins
 By driller performing actual drilling on site or contractor
 Date November 24, 2000