WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 81588
Permit No.
Basin 212

NOTICE OF INTENT NO. 16897

1. OWNER Gordon Gaming Corp
MAILING ADDRESS P.O. Box 98888
Las Vegas, NV 89193-8888

ADDRESS AT WELL LOCATION 2533 Las Vegas Blvd

2. LOCATION NE ¼ NE ¼ Sec. 09 T. 21 N/S R. 61 E. Clark County
PERMIT NO. ~~16897~~ Issued by Water Resources | 162-09-501-003 Parcel No. | N/A Subdivision Name

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☐ Deepen ☒ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Silty Clay		0	3	3
Caliche		3	5	2
Silty Clay		5	8	3
Sandy Clay w/ caliche lenses from 13-18' bgs		8	23	15

* well was abandoned by pulling casing + placing a neat cement grout from the bottom of well to surface.

DCNR/DWR Received DEC 13 2000 LAS VEGAS OFFICE

Date started Nov 16, 2000
Date completed Nov 16, 2000

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 23 Feet Depth Cased 20 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
8	Inches	0	Feet	1.5	Feet
6	Inches	1.5	Feet	23	Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
Schedule 40				

Perforations:
Type perforation Slotted
Size perforation 0.020
From 0 feet to 20 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 5
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 7 feet to 23 feet

9. WATER LEVEL
Static water level 10 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Western Technologies (Contractor)
Address 3611 W. Tompkins (Contractor)
Las Vegas, NV 89103
Nevada contractor's license number issued by the State Contractor's Board N11761
Nevada driller's license number issued by the Division of Water Resources, the on-site driller
Signed (By driller performing actual drilling on site or contractor)
Date 12/01/00

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627