WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 81589
Permit No.
Basin 212

NOTICE OF INTENT NO. 16891

1. OWNER Union Oil Co
MAILING ADDRESS P.O. Box 7600
Brea, CA 92822-7600

ADDRESS AT WELL LOCATION 2600 Fremont St
Las Vegas NV

2. LOCATION NE ¼ NW ¼ Sec. 01 T. 21 N/S R 61 E Clark County

PERMIT NO. ____ Issued by Water Resources | 162-01-103-001 Parcel No. | Subdivision Name

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☐ Deepen ☒ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Gravelly Sand (fill)		0	1	1
Caliche		1	2	1
Silty Sand		2	5	3
Clayey Sand		5	7.5	2.5
Sandy Silt		7.5	10	2.5
Silty Sand		10	13	3
Clayey Sand		13	15	2

* well was abandoned by pulling the casing + placing a neat cement grout from bottom of well to surface.

DCNR/DWR Received DEC 13 2000 LAS VEGAS OFFICE

Date started Nov 16, 2000
Date completed Nov 16, 2000

7. WELL TEST DATA

TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 17 Feet Depth Cased 15 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
8 Inches	0 Feet	1.5 Feet
6 Inches	1.5 Feet	17 Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
Schedule 40			0	15

Perforations:
Type perforation Slotted
Size perforation 0.020
From 0 feet to 15 feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal
Placement Method: ☐ Pumped ☒ Poured

Seal Type:
☐ Neat Cement
☐ Cement Grout
☒ Concrete Grout

Gravel Packed: ☐ Yes ☐ No
From ____ feet to ____ feet

9. WATER LEVEL
Static water level 10 feet below land surface
Artesian flow ____ G.P.M. ____ P.S.I.
Water temperature ____ °F Quality ____

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Western Technologies
Contractor
Address 3611 W. Tompkins
Contractor
Las Vegas, NV 89103

Nevada contractor's license number issued by the State Contractor's Board M1761

Nevada driller's license number issued by the Division of Water Resources, the on-site driller

Signed [signature]
By driller performing actual drilling on site or contractor

Date 12/01/00

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627