WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 81630
Permit No.
Basin 163

NOTICE OF INTENT NO. 21738

1. OWNER David A Merrill Vidler Water Co
MAILING ADDRESS 3264 Goni Rd. Ste 153 Carson City NV
ADDRESS AT WELL LOCATION West McVicar Mile ¼ mile

2. LOCATION NW ¼ NE ¼ Sec. 14 T. 25 N/S R. 57 E. Clark County
PERMIT NO. (Issued by Water Resources) 219-14-000 00 (Parcel No.) Subdivision Name

3. WORK PERFORMED
☑ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☑ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Coarse Sand + Silt Brown		0	10	10
Coarse Sand + Silt		10	20	10
Gravel + Silt		20	30	10
Gravel in a clay Maytrix		30	40	10
Gravel in a clay Maytrix		40	50	10
Gravel in clay Maytrix		50	60	10
Gravel in silty Maytrix		60	70	10
Gravel in silty Maytrix		70	80	10
Gravel in silty Maytrix		80	90	10
Gravel in in a rich Clay Maytrix		90	100	10
Gravel in silty Maytrix		100	110	10
Silt + Clay interbeds		110	120	10
Gravel in a silty Maytrix		130	170	40
Clast supported Maytrix		170	180	10
Gravel + Sand		180	190	10
Gravel + Silts		190	200	10
Gravel in Sandy Maytrix		200	210	10
Gray Worn Coarse Sand & Gravel		210	220	10
Coarse Sand + Gravel		220	250	30
Silt + Gravel		250	270	20
Conglomerate Clast Supported Lakebed		270	290	20
Gravel + Sand		290	350	60

Date started 10-11 2000
Date completed 10-14 2000

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 350 Feet Depth Cased Feet

HOLE DIAMETER (BIT SIZE)

		From	To
11 Inches		0 Feet	350 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
4"		Sec 80	350	0

Perforations:
Type perforation .050 Screen
Size perforation
From 295 feet to 340 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 50'
Placement Method: ☐ Pumped ☑ Poured
Seal Type: ☐ Neat Cement ☑ Cement Grout ☐ Concrete Grout

Gravel Packed: ☑ Yes ☐ No
From 350 feet to 50 feet

9. WATER LEVEL
Static water level 297 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature 78 °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name ABA Compliance Corp. (Contractor)
Address 3915 West Hacienda Avenue Ste #111 Las Vegas Nev. 89118 (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 0048704
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2021
Signed Michael Dale Wells (By driller performing actual drilling on site or contractor)
Date 11-30-2000

RECEIVED NOV 30 2000 LAS VEGAS CONRADY

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627