WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 81638
Permit No. 65642
Basin 131-B

NOTICE OF INTENT NO. 44708

1. OWNER JOHN WILLIAMS
MAILING ADDRESS HC 65 BOX 142
AUSTIN, NV 89310

ADDRESS AT WELL LOCATION KINGSTON, NV

2. LOCATION NW 1/4 SE 1/4 Sec. 36 T ~~14N~~ 16N N/S R 43E E ~~NYE~~ LANDER County
PERMIT NO. 65642 (Issued by Water Resources) 003-155-02 (Parcel No.) KINGSTON TOWNSITE (Subdivision Name)

3. **WORK PERFORMED**
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. **PROPOSED USE**
[ ] Domestic [ ] Irrigation [ ] Test
[X] Municipal/Industrial Commercial [ ] Monitor [ ] Stock

5. **WELL TYPE**
[ ] Cable [X] Rotary RVC
[X] Air [ ] Other

6. **LITHOLOGIC LOG**

Material	Water Strata	From	To	Thickness
TOPSOIL		0	1	1
GRAVEL & SAND		1	10	9
SILT & GRAVEL	190	10	220	210

RECEIVED
00 NOV -1 AM 11:56
STATE ENGINEER'S OFFICE

Date started 09/18/2000, 19__
Date completed 09/21/2000, 19__

7. **WELL TEST DATA**
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
18		4

8. **WELL CONSTRUCTION**
Depth Drilled 220 Feet Depth Cased 220 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10 5/8	Inches	0	Feet	220	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	13	.188	+1	220

Perforations:
Type perforation MILLSLOT
Size perforation 3/16 X 3
From 200 feet to 220 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 100
Placement Method: [ ] Pumped [X] Poured
Seal Type: [X] Neat Cement [ ] Cement Grout [ ] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 100 feet to 220 feet

9. **WATER LEVEL**
Static water level 185 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature C °F Quality

10. **DRILLER'S CERTIFICATION**
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name HACKWORTH DRILLING, INC (Contractor)
Address P.O.BOX 850 (Contractor)
ELKO,NV 89803
Nevada contractor's license number issued by the State Contractor's Board 020582
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1689
Signed [signature] (By driller performing actual drilling on-site or contractor)
Date 09/27/2000

USE ADDITIONAL SHEETS IF NECESSARY