WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 81647
Permit No.
Basin 101

NOTICE OF INTENT NO. 44167

1. OWNER Dave Stix
MAILING ADDRESS 4830 Farm District Road
Fernley, NV 89408

ADDRESS AT WELL LOCATION 12255 Carr Lane, Fallon, NV 89406

2. LOCATION NW 1/4 SW 1/4 Sec. 8 T 19N N/S R 27E E Churchill County
PERMIT NO. (Issued by Water Resources) | Parcel No. 7-141-17 | Subdivision Name

3. **WORK PERFORMED**
[X] New Well [X] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. **PROPOSED USE**
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. **WELL TYPE**
[ ] Cable [X] Rotary [ ] RVC
[ ] Air [ ] Other

6. **LITHOLOGIC LOG**

Material	Water Strata	From	To	Thickness
Brown Sand		0	30	30
Brown Clay		30	75	45
Brown Sand		75	110	35
Brown Clay		110	125	15
Brown Sand	XX	125	140	15

RECEIVED 2000 OCT 30 PM 1:47 NEVADA DIVISION OF WATER RESOURCES

Date started 09/12/2000, 19__
Date completed 09/13/2000, 19__

7. **WELL TEST DATA**
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
40		1hr

8. **WELL CONSTRUCTION**
Depth Drilled 140 Feet Depth Cased 140 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10 Inches	0 Feet	140 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.92	.188	0	10
6 PVC	3.92	.258	10	140

Perforations:
Type perforation Saw Cut
Size perforation 1/8
From 130 feet to 140 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50
Placement Method: [X] Pumped [ ] Poured
Seal Type: [ ] Neat Cement [X] Cement Grout [ ] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 50 feet to 140 feet

9. **WATER LEVEL**
Static water level 50 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature Cool °F Quality unknown

10. **DRILLER'S CERTIFICATION**
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Parsons Drilling, Inc. (Contractor)
Address P.O. Box 1264 (Contractor)
Fallon Nv. 89407
Nevada contractor's license number issued by the State Contractor's Board 29064
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1753
Signed Wayne Parsons (By driller performing actual drilling on-site or contractor)
Date 10/23/2000

USE ADDITIONAL SHEETS IF NECESSARY