WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

# WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 81651
Permit No.
Basin 01

NOTICE OF INTENT NO. 43787

1. OWNER Clyde Smart JR
MAILING ADDRESS 990 Taylor Pl Fallon NV 89406
ADDRESS AT WELL LOCATION 990 Taylor PL

2. LOCATION NE ¼ NE ¼ Sec. 35 T. 19 N/S R. 28 E. Churchill County
PERMIT NO. (Issued by Water Resources) Parcel No. 008-811-83 Subdivision Name

3. WORK PERFORMED
☐ New Well ☒ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| Sand | | 0 | 45 | 45 |
| Clay | | 45 | 65 | 20 |
| Sand | | 65 | 103 | 38 |

RECEIVED 00 OCT 25 AM 11:44 STATE ENGINEER'S OFFICE

Date started 10-5, 2000
Date completed 10-6, 2000

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☒ Pump ☐ Air Lift

| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|---|---|
| 25 | 6 | 4 |

8. WELL CONSTRUCTION
Depth Drilled 103 Feet Depth Cased 103 Feet

HOLE DIAMETER (BIT SIZE)

| | From | To |
|---|---|---|
| 12" Inches | 0 Feet | 103 Feet |
| Inches | Feet | Feet |
| Inches | Feet | Feet |

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|---|---|---|---|---|
| 6" | 3.2 | .280 | 0 | 103 |

Perforations:
Type perforation SLOTS
Size perforation 1/8 x 3"
From 98 feet to 103 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 98 feet to 103 feet

9. WATER LEVEL
Static water level 12' feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name FARRIS DRILLING (Contractor)
Address PO Box 5205 (Contractor)
Fallon NV 89407
Nevada contractor's license number issued by the State Contractor's Board 43145
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2082
Signed [signature] (By driller performing actual drilling on site or contractor)
Date 10-23-00

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627