WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 81656
Permit No.
Basin 109

NOTICE OF INTENT NO. 45404

1. OWNER Flying M Cattle
MAILING ADDRESS 11 Pine Grove Rd Yerington NV 89447
ADDRESS AT WELL LOCATION 9 mile Ranch

2. LOCATION NE ¼ SW ¼ Sec. 11 T 6 N N/S R 27 E Mineral County
PERMIT NO. 57265 (Issued by Water Resources) Parcel No. Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☒ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☒ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Topsoil	No	0	2	2
White Ash	No	2	3	1
Brn Clay	No	3	14	11
Blue Sand & Clay	yes	14	18	4
Blue Clay w/ Sand	yes	18	24	6
Gravel & Boulders	yes	24	56	32
Sand & Gravel	yes	56	64	8
Brown Clay	no	64	68	4
Coarse Sand Fine Gravel	yes	68	92	24
Brown clay	no	92	101	9
Sand & Gravel	yes	101	105	4
Brn Clay w/ Sand	No	105	144	39
Sand & Gravel	yes	144	148	4
Sand & Gravel w/ clay	yes	148	160	12
Sand & Gravel	yes	160	164	4
Sandy Brn Clay	no	164	170	6
Coarse Sand & Gravel	yes	170	174	4
Brn Clay w/ Gravel	yes	174	192	18
Brn Clay	no	192	196	4
Brn Clay & Gravel	yes	196	208	12
Sand Gravel Rock	yes	208	218	10
Brown Clay	no	218	221	3
Sand Gravel Rock	yes	221	251	30
Black Sandstone	yes	251	300	49
Brn Clay	no	300	301	1
Black Sandstone	yes	301	340	39

Date started 9/17/00, 19
Date completed 10/1/00, 19

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☒ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
650	93	5

8. WELL CONSTRUCTION
Depth Drilled 340 Feet Depth Cased 340 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
26 Inches	0 Feet	340 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
16"		.250	+2	100
16"		.250	100	340

Perforated interval

Perforations:
Type perforation Saw
Size perforation 1/8
From 100 feet to 340 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 52
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 52 feet to 340 feet

9. WATER LEVEL
Static water level +2 feet below land surface
Artesian flow 15 G.P.M. 1 P.S.I.
Water temperature 68 °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Riverside Inc (Contractor)
Address PO Box 722 (Contractor)
Parma ID 83660
Nevada contractor's license number issued by the State Contractor's Board 0044881
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1484
Signed (By driller performing actual drilling on site or contractor)
Date 10/24/00

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627