WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 81673
Permit No.
Basin 188

NOTICE OF INTENT NO. 44099

1. OWNER JOE RICK
MAILING ADDRESS 315 BERRINGTON AVE
EAST DUNDEE, IL 60118

ADDRESS AT WELL LOCATION
2 MILES SOUTH OF MOOR EXCHANGE
Wells, NV

2. LOCATION NE 1/4 NW 1/4 Sec. 23 T ~~36N~~ 37N N/S R 63E E ELKO County

PERMIT NO. | Issued by Water Resources | 008560015 Parcel No. | Subdivision Name

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[ ] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
CEMENTED GRAVEL		0	145	145
LOOSE GRAVEL	X	145	146	1
CEMENTED GRAVEL		146	200	54

RECEIVED 00 NOV 17 AM 11:23 STATE ENGINEER'S OFFICE

Date started 10/16/00 , 19__
Date completed 10/23/00 , 19__

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
Apoak	4		7.5HR

8. WELL CONSTRUCTION
Depth Drilled 200 Feet Depth Cased 200 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10 5/8	Inches	0	Feet	200	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.92	188	+2	200

Perforations:
Type perforation MILL SLOT
Size perforation 3/16" X 3"
From 180 feet to 200 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 51
Placement Method: [ ] Pumped [X] Poured
Seal Type: [ ] Neat Cement [ ] Cement Grout [ ] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 51 feet to 200 feet

9. WATER LEVEL
Static water level 130 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature COLD °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Fertig Drilling Company (Contractor)
Address P.O. BOX 525 (Contractor)
ELKO, NV 89803

Nevada contractor's license number issued by the State Contractor's Board 0031904

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1584

Signed [signature] (By driller performing actual drilling on-site or contractor)
Date 11-8-00