

OFFICE USE ONLY
 Log No. 81627
 Permit No. 99
 Basin

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 44292

1. OWNER Gerald and Annika Martin ADDRESS AT WELL LOCATION 15911
 MAILING ADDRESS 12002 Himalaya Choke cherry Ln. Reno
Reno NV 89506 NV. 89506
 2. LOCATION SE 1/4 NE 1/4 Sec 3 T 23 N/S R. 18 E Washoe County
 PERMIT NO. 078-271-17 Sierra Ranchos Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other MVD

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Sandy Top soil		0	5	5
Green Clay		5	15	10
Sand		15	30	15
Rock		30	50	20
Br. Shale		50	75	25
Br. Clay		75	135	60
Red Rock		135	141	6
Gray Clay		141	160	19
Gray Cody with Sand		160	225	65
Hard Rock cap		225	230	5
Red Rock (Hard)		230	265	35
Rock with Fractures		265	285	20
Clay with sand layers		285	310	25
Rock (Hard)		310	335	25
Rock with Fractures		335	395	60

8. WELL CONSTRUCTION
 Depth Drilled 395 Feet Depth Cased 380 Feet
 HOLE DIAMETER (BIT SIZE)
 From 0 To 395
10 5/8 Inches. Feet Feet
 Inches. Feet Feet
 Inches. Feet Feet
 CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>10.78</u>	<u>1 9/8</u>	<u>2+</u>	<u>380</u>

Perforations:
 Type perforation Saw Slot
 Size perforation 3/32 x 3/12"
 From 380 feet to 200 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 Surface Seal: Yes No Seal Type:
 Depth of Seal 50' Neat Cement
 Placement Method: Pumped Concrete Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 395 feet to 50' feet

9. WATER LEVEL
 Static water level 37 feet below land surface
 Artesian flow _____ G.P.M. P.S.I.
 Water temperature Cold °F Quality Good

Date started July 27 2000
 Date completed Aug 5 2000

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>45</u>	<u>NA</u>	<u>4</u>

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name John F Olenki Contractor
 Address 15045 Red Rock Rd Contractor
Reno NV 89506
 Nevada contractor's license number 50343
 issued by the State Contractor's Board
 Nevada driller's license number issued by the 1656
 Division of Water Resources, the on-site driller
 Signed John F Olenki
 By driller performing actual drilling on site or contractor
 Date 8/10/00