

OFFICE USE ONLY  
 Log No. 81683  
 Permit No. 890  
 Basin [Signature]  
 NOTICE OF INTENT NO. 31385

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

1. OWNER Kay Kimber ADDRESS AT WELL LOCATION Montello Valley CRURAL  
 MAILING ADDRESS Box 96  
Montello, NV 89830  
 2. LOCATION NE 1/4 NE 1/4 Sec 33 T 40 N/S R 69 E 31/40 County  
 PERMIT NO. 010-592-001 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>Soil</u>		<u>0</u>	<u>1</u>	
<u>Brown Sandstone</u>		<u>1</u>	<u>47</u>	
<u>Volcanic Ash</u>		<u>47</u>	<u>52</u>	
<u>Brown Sandstone</u>	<u>X</u>	<u>52</u>	<u>79</u>	
<u>Green Shale</u>		<u>79</u>	<u>110</u>	

8. WELL CONSTRUCTION  
 Depth Drilled 108 Feet Depth Cased 108 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 12 Inches To 108 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>8 7/8</u>	<u>28.55</u>	<u>7/8"</u>	<u>+1</u>	<u>108</u>

Perforations:  
 Type perforation Touch cut  
 Size perforation 3 x 18  
 From 28 feet to 108 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Neat Cement  
 Cement Grout  
 Concrete Grout  
 Depth of Seal 51  
 Placement Method:  Pumped  Poured  
 Gravel Packed:  Yes  No  
 From 55 feet to 108 feet

9. WATER LEVEL  
 Static water level 43 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature cold °F Quality not tested

Date started June 20 - 2000  
 Date completed June 22 - 2000

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>20+</u>	<u>40</u>	<u>2</u>
<u>20 GPM pump test 30 min</u>		

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge  
 Name R.D. Reynolds Contractor  
 Address Wells, NV Contractor  
 Nevada contractor's license number issued by the State Contractor's Board 014410  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1390  
 Signed [Signature]  
 By driller performing actual drilling on site or contractor  
 Date 7-15-00

RECEIVED  
 00 SEP - 1 AM 11:26  
 STATE ENGINEERS OFFICE