

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 31386

1. OWNER Bill & Joy Swenson ADDRESS AT WELL LOCATION Picket Valley  
 MAILING ADDRESS \_\_\_\_\_

2. LOCATION NE 1/4 NE 1/4 Sec 27 T. 38 N/S R. 69 E 31/40 County \_\_\_\_\_  
 PERMIT NO. 10-52N-42-1 AREA West  
 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>Soil</u>		<u>0</u>	<u>3</u>	
<u>Fine grained clay</u>		<u>3</u>	<u>85</u>	
<u>Sandy clay</u>		<u>85</u>	<u>195</u>	
<u>1/2 minus gravel X</u>		<u>195</u>	<u>203</u>	
<u>Small amount of water</u>				
<u>around 170' - lets at</u>				
<u>200'</u>				

8. WELL CONSTRUCTION  
 Depth Drilled 223 Feet Depth Cased 223 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From To  
10 Inches 0 Feet 80 Feet  
8 Inches 80 Feet 223 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 CASING SCHEDULE  

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6</u>	<u>12.94</u>	<u>.188</u>	<u>72</u>	<u>203</u>

 Perforations:  
 Type perforation Factory Milled  
 Size perforation \_\_\_\_\_  
 From 203 feet to 223 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 55 \_\_\_\_\_  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From 55 feet to 203 feet

RECEIVED  
 0828 - 11:26  
 STATE ENGINEER

Date started July 5-00  
 Date completed July 11-00

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>20+</u>	<u>40</u>	<u>2</u>

9. WATER LEVEL  
 Static water level: 115 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature cold °F Quality untested / Good

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name R.V. Reynolds Contractor  
 Address Wells, Mo Contractor  
 Nevada contractor's license number issued by the State Contractor's Board 014410  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1390  
 Signed 191 By driller performing actual drilling on site or contractor  
 Date 7-15-00