WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT
Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 81687
Permit No.
Basin 106

NOTICE OF INTENT NO. 44900

1. OWNER Jeffrey B. Pisciotta
MAILING ADDRESS Box 336
Gardnerville NV 89410
ADDRESS AT WELL LOCATION 1520 Moss Circle
Gardnerville NV 89410

2. LOCATION SE ¼ NW ¼ Sec. 18 T. 10 N S R. 22 E. Douglas County
PERMIT NO. (Issued by Water Resources) Parcel No. 37-501-120 Subdivision Name Holbrook Highlands

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[ ] Air [X] Other Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Andesite Rubble		0	123	123
Diorite Boulders		123	138	15
Andesite Rubble		138	206	68
Andesite Rubble mixed with Bc Clay		206	247	41
Broken Andesite	vv	247	335	88

Note
Developed Well @ 300' made only 5 GPM Deepended to 335'

RECEIVED
AUG 28 1 PM 3:50
STATE ENGINEER'S OFFICE

Date started 8-4, 00
Date completed 8-12, 00

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
Air	15		2 hrs

8. WELL CONSTRUCTION
Depth Drilled 335 Feet Depth Cased 335 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
10 5/8 Inches		0 Feet	60 Feet
9 7/8 Inches		60 Feet	300 Feet
6 7/8 Inches		300 Feet	335 Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	17	.188	+2	300
5"	12	.188	295	335

Perforations:
Type perforation Factory Milled
Size perforation 1/8 x 3
From 260 feet to 300 feet
From 295 feet to 335 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50'
Placement Method: [X] Pumped [ ] Poured
Seal Type: [X] Neat Cement [ ] Cement Grout [ ] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 50 feet to 300 feet

9. WATER LEVEL
Static water level 95 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature Cool °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Eddco Exploration Inc (Contractor)
Address 7780 Curry Rd (Contractor)
Fallon NV 89406
Nevada contractor's license number issued by the State Contractor's Board 27673 A
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1586
Signed [signature] (By driller performing actual drilling on site or contractor)
Date 8-20-00

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627