

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY

Log No. 81695  
 Permit No. \_\_\_\_\_  
 Basin 05

NOTICE OF INTENT NO. 45072

1. OWNER Newmont Mining Corp ADDRESS AT WELL LOCATION Loas Tree Mine (R16)  
 MAILING ADDRESS P.O. Box 388  
Valmy, Nevada 89438  
 2. LOCATION NE 1/4 SW 1/4 Sec. 17 T. 34 N S R. 42 E Humboldt County  
 PERMIT NO. \_\_\_\_\_ Issued by Water Resources Parcel No. \_\_\_\_\_ Subdivision Name \_\_\_\_\_

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>Alluvium</u>		<u>0</u>	<u>300</u>	<u>300</u>
<u>Gravel Sand</u>				
<u>Hole Cased</u>		<u>280</u>	<u>300</u>	<u>20'</u>
<u>only Cased to 280'</u>				
<u>71-#50 Bags #8 Sand</u>		<u>170</u>	<u>280</u>	<u>110</u>
<u>65-#50 Bags 3/4 Hole Plug</u>		<u>50</u>	<u>170</u>	<u>120</u>
<u>19 #94 Bags Cement</u>		<u>13</u>	<u>50</u>	<u>53</u>

8. WELL CONSTRUCTION  
 Depth Drilled 300 Feet Depth Cased 280 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From To  
1 1/2 Inches 0 Feet 20 Feet  
5 3/4 Inches 20 Feet 300 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 3/8</u>		<u>.156</u>	<u>73</u>	<u>20</u>
<u>1 1/2"</u>	<u>Sch 80 PVC Blank</u>		<u>73</u>	<u>180</u>

Perforations:  
 Type perforation 0.020 Horiz. Slot  
 Size perforation 0.020  
 From 180 feet to 280 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 Surface Seal:  Yes  No Seal Type:  Neat Cement  
 Depth of Seal 73 - 50 \_\_\_\_\_  Cement Grout  
 Placement Method:  Pumped  Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From 170 feet to 280 feet

*Plugged by Well Log 112116*

Date started 7/26/00, 19\_\_\_\_  
 Date completed 7/27/00, 19\_\_\_\_

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailor <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift			
<u>EST</u>		<u>N/A</u>	<u>4 1/2</u>

9. WATER LEVEL  
 Static water level 205.3 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Eklund Drilling Contractor  
 Address P.O. Box 2748 Contractor  
Elko, Nevada 89803  
 Nevada contractor's license number issued by the State Contractor's Board 0030823  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1879  
 Signed Bruce Cliff By driller performing actual drilling on site or contractor  
 Date 7/27/00