


OFFICE USE ONLY  
Log No. 81700  
Permit No. \_\_\_\_\_  
Basin 163



NOTICE OF INTENT NO. 42246

PRINT OR TYPE ONLY  
DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

1. OWNER Les Yoho ADDRESS AT WELL LOCATION 25 Sandefer Rd Dayton  
MAILING ADDRESS 25 Sandefer Rd Dayton NV 89403  
2. LOCATION NW 1/4 NE 1/4 Sec 5 T 16 N/S R 22 E Lyon County  
PERMIT NO. 16-311-02 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Sand		0	15	
Sandy Br. Clay		15	75	
Small Gravel		75	80	
Sandy Orange Clay		80	120	
Gravelly Orange Clay		120	130	
Sandy Br. Clay		130	175	
Sand and Gravels		175	190	
Br Clay		190	197	
Sand Gravel		197	210	

8. WELL CONSTRUCTION  
Depth Drilled 210 Feet Depth Cased 210 Feet

HOLE DIAMETER (BIT SIZE)  
From 10 5/8 Inches To 0 Feet 210 Feet  
Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>10 5/8</u>		<u>-.188</u>	<u>+2</u>	<u>170'</u>

Perforations:  
Type perforation Mill Slat  
Size perforation 2/32  
From 170 feet to 210 feet  
From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
Depth of Seal 50'  Neat Cement  
Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout

Gravel Packed:  Yes  No  
From 50 feet to 210 feet

Date started 9-21 1900  
Date completed 9-22 1900

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>75 f</u>	<u>76 ft</u>	<u>3 HR</u>

9. WATER LEVEL  
Static water level 5.5 feet below land surface  
Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
Water temperature cold °F Quality \_\_\_\_\_

10. DRILLER'S CERTIFICATION  
This well was drilled under my supervision and the report is true to the best of my knowledge.  
Name Nevada Drilling Contractor  
Address 75 Lewers CR Rd Carson City NV Contractor  
Nevada contractor's license number issued by the State Contractor's Board 13697-A  
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1790  
Signed Mr. Tom By driller performing actual drilling on site or contractor  
Date 10-10-00