

22c

WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 81703
Permit No. 162
Basin
NOTICE OF INTENT NO. 20735

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

1. OWNER Sundance Homes
MAILING ADDRESS 1930 S. Red Rock
Pahrump, NV 89048

ADDRESS AT WELL LOCATION
1930 S. Red Rock

2. LOCATION SE 1/4 SE 1/4 Sec. 20 T 20S
PERMIT NO. 39-044-13
Issued by Water Resources Parcel No.

N/S R 53E E Nye County
Calvada Valley Subdivision Name

3. WORK PERFORMED
X New Well Deepen
Replace Abandon
Recondition Other

4. PROPOSED USE
X Domestic Municipal/Industrial
Irrigation Monitor
Test Stock
5. WELL TYPE
Cable Air
X Rotary Other
RVC

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
brown clay		0	3	3
grey caleche with gravel		3	5	2
grey caleche		5	9	4
grey clay		9	22	13
See next line		22	37	15
grey clay with caleche strings				
brown clay	x	37	170	133

8. WELL CONSTRUCTION

Depth Drilled 170 Feet
Depth Cased 170+1 Feet

HOLE DIAMETER (BIT SIZE)


	From	To
11 Inches	0	170
Inches		
Inches		

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	3.7	.280	0	170

Perforations:
Type perforation sawcut
Size perforation .188
From 140 feet to 170 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: Yes No
Depth of Seal 50
Placement Method: Pumped Poured
Seal Type: Neat Cement Cement Grout Concrete Grout
Gravel Packed: Yes No
From 50 feet to 170 feet



9. WATER LEVEL
Static water level 59 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature cool °F Quality good

Date started 10/5/00
Date completed 10/5/00

7. WELL TEST DATA

TEST METHOD:	Bailer	Pump	Air Lift
G.P.M.	Draw Down (Feet Below Static)	Time (Hours)	
0			

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Strickland Construction Co., Inc.
Address 2301 Winery Road, Suite 2
Pahrump, NV 89048
Nevada contractor's license number issued by the State Contractor's Board 40277
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2086
Signed [Signature]
By driller performing actual drilling on-site or contractor
Date 10-6-00

