

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 81704
Permit No. 762
Basin
NOTICE OF INTENT NO. 20737

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

1. OWNER CR Homes
MAILING ADDRESS 1791 W. Moose
Pahrump, NV 89048
2. LOCATION NW 1/4 NW 1/4 Sec. 29 T 20S
PERMIT NO. 39-021-15
Issued by Water Resources Parcel No.

ADDRESS AT WELL LOCATION 1791 W. Moose
N/S R 53E E Nye County
Calvada Valley Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other
 Domestic Municipal/Industrial

4. PROPOSED USE
 Irrigation Test Cable Rotary RVC
 Monitor Stock Air Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
brown clay		0	3	3
grey clay		3	8	5
See next line		8	17	9
grey clay with caleche strings				
grey caleche		17	34	17
See next line		34	42	8
grey clay with caleche strings				
brown clay	x	42	82	40
See next line	x	82	140	58
brown clay with caleche strings				

8. WELL CONSTRUCTION

Depth Drilled 140 Feet Depth Cased 140+1 Feet


HOLE DIAMETER (BIT SIZE)

	From	To	
11 Inches	0	140	Feet
Inches			Feet
Inches			Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	3.7	.280	0	140

Perforations:
Type perforation sawcut
Size perforation .188
From 125 feet to 140 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet
Surface Seal: Yes No Seal Type:
Depth of Seal 50 Neat Cement
Placement Method: Pumped Cement Grout
 Poured Concrete Grout
Gravel Packed: Yes No
From 50 feet to 140 feet



9. WATER LEVEL
Static water level 55 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature cool °F Quality good

Date started 10/5/00 19__
Date completed 10/5/00 19__

7. WELL TEST DATA

TEST METHOD:	Bailer	Pump	Air Lift
G.P.M.	Draw Down (Feet Below Static)		Time (Hours)

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Strickland Construction Co., Inc. Contractor
Address 2301 Winery Road, Suite 2 Contractor
Pahrump, NV 89048
Nevada contractor's license number issued by the State Contractor's Board 40277
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2086
Signed *Pruey Strickland*
By driller performing actual drilling on-site or contractor
Date 10-15-00

