


OFFICE USE ONLY
 Log No. 81708
 Permit No. _____
 Basin 162



PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 20741

1. OWNER **Nationwide Homes**
 MAILING ADDRESS **4080 W. Maple Pahrump, NV 89048**

ADDRESS AT WELL LOCATION **4080 W. Maple**

2. LOCATION **NE 1/4 NE 1/4 Sec. 23 T 20S** N/S R **52E E Nye** County
 PERMIT NO. **41-443-30** Parcel No. _____ Subdivision Name _____
 Issued by Water Resources _____

3. WORK PERFORMED
 New Well Replace Recondition Domestic
 Deepen Abandon Other Municipal/Industrial Irrigation Test Cable Rotary RVC
 Monitor Stock Air Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
brown clay		0	3	3
grey clay		3	14	11
grey caleche		14	16	2
brown clay		16	31	15
grey clay		31	52	21
grey caleche	x	52	97	45
See next line	x	97	140	43
brown clay with caleche string				

8. WELL CONSTRUCTION
 Depth Drilled **140** Feet Depth Cased **140+1** Feet

HOLE DIAMETER (BIT SIZE)
 From _____ To _____
11 Inches **0** Feet **140** Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	3.7	.280	0	140

Perforations:
 Type perforation **sawcut**
 Size perforation **.188**

From **.125** feet to **140** feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal **50** Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout

Gravel Packed: Yes No
 From **50** feet to **140** feet



9. WATER LEVEL
 Static water level **57** feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature **cool** °F Quality **good**

Date started **10/12/00** _____ 19____
 Date completed **10/12/00** _____ 19____

7. WELL TEST DATA
 TEST METHOD: Bailer Pump Air Lift
 G.P.M. _____ Draw Down (Feet Below Static) _____ Time (Hours) _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name **Strickland Construction Co., Inc.** Contractor
 Address **2301 Winery Road, Suite 2** Contractor
Pahrump, NV 89048

Nevada contractor's license number issued by the State Contractor's Board **40277**

Nevada driller's license number issued by the Division of Water Resources, the on-site driller **2086**

Signed *Larry Strickland*
 By driller performing actual drilling on-site or contractor

Date **10-18-00**

