

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 44592

1. OWNER Tom Mair ADDRESS AT WELL LOCATION Lower Colony RD Wellington NV
 MAILING ADDRESS N/A

2. LOCATION NW 1/4 NE 1/4 Sec 34 T. 11 N/S R. 23 E Lyon County
 PERMIT NO. N/A Issued by Water Resources Parcel No. 10-351-51 Subdivision Name Lot #3

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other Misc

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>Small Cobbles</u>		<u>1</u>	<u>3</u>	
<u>Cobbles boulders</u>		<u>3</u>	<u>18</u>	
<u>Small Cobbles</u>		<u>18</u>	<u>34</u>	
<u>Clay</u>		<u>34</u>	<u>41</u>	
<u>Dark Decomposed Granite</u>		<u>41</u>	<u>86</u>	
<u>Granite Boulders</u>		<u>86</u>	<u>105</u>	
<u>D.S.</u>		<u>105</u>	<u>220</u>	

8. WELL CONSTRUCTION
 Depth Drilled 220 Feet Depth Cased 220 Feet

HOLE DIAMETER (BIT SIZE)
 From _____ To _____
1 5/8 Inches _____ Feet 220 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>1 5/8</u>	<u>13</u>	<u>1.88</u>	<u>1</u>	<u>220</u>
		<u>PVC 31</u>	<u>20</u>	<u>220</u>

Perforations:
 Type perforation Mechanical Perforation
 Size perforation 3/16 x 4 x 4 holes
 From 200 feet to 220 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 1.10 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout

Gravel Packed: Yes No
 From 180 feet to 220 feet

9. WATER LEVEL
 Static water level 1.14 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature C °F Quality Good

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name James D. Miller, Jr. Contractor
 Address P.O. Box 523 S.S. NV 89409 Contractor
 Nevada contractor's license number issued by the State Contractor's Board 0031841
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1876
 Signed [Signature] By driller performing actual drilling on site or contractor
 Date _____

Date started 7/18/00, 19____
 Date completed 7/21/00, 19____

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>25-30</u>		<u>2 1/2 hrs</u>