WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 81748
Permit No.
Basin 207

NOTICE OF INTENT NO. 43185

1. OWNER Rick Hendrix
MAILING ADDRESS Po Box 185 Lund NV 89317
ADDRESS AT WELL LOCATION 965 200 East Lund NV

2. LOCATION NE ¼ SE ¼ Sec. 33 T. 12 N/S R. 62 E. White Pine County
PERMIT NO. N/A (Issued by Water Resources) 011-490-01 (Parcel No.) Lund town Site Survey (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☒ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Silty top Soil		0	4	
Sinkty clay		4	14	
gravel		14	14.5	
Silty clay		14.5	21	
gravel		21	22	
clay		22	47	
gravel	water	47	47.5	
clay		47.5	53	
gravel	water	53	55	
clay		55	62	
gravel	water	62	63	
clay		63	73	
gravel	water	73	75	
clay		75	85	
gravel	water	85	87	
clay		87	105	
gravel	water	105	107	
clay		107	115	
gravel	water	115	117	

RECEIVED 00 SEP 15 AM 11:21 STATE ENGINEER'S OFFICE

Date started July 28, 19 2000
Date completed Aug 11, 19 2000

7. WELL TEST DATA
TEST METHOD: ☒ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
60	5'	1 hr.

8. WELL CONSTRUCTION
Depth Drilled 117 Feet Depth Cased 117 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
12 Inches		0 Feet	50 Feet
10 Inches		50 Feet	117 Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8 5/8		.188	-1	117

Perforations:
Type perforation torch
Size perforation 1/8 x 6"
From feet to feet
From 75 feet to 117 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout
Gravel Packed: ☒ Yes ☐ No
From 50 feet to 117 feet

9. WATER LEVEL
Static water level 45 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature Cold °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Orvan R Maynard (Contractor)
Address Po Box 64 Lund NV 89317 (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 047226
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1556
Signed Orvan Maynard (By driller performing actual drilling on site or contractor)
Date Aug 28-00

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627