WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 81750
Permit No.
Basin 82

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 6165

1. OWNER Richard Hoy (Capriotte Const.)
MAILING ADDRESS 2945 Mill St
Reno NV 89508

ADDRESS AT WELL LOCATION
~~Imediat~~ Imediatly south side of Truckee River in Lockwood

2. LOCATION ¼ SW ¼ Sec. 16 T. 19 N/S R. 21 E Storey County

PERMIT NO. 34835-34836 W-171 Issued by Water Resources | Parcel No. | Subdivision Name

3. TYPE OF WORK
New Well ☑ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☐ Irrigation ☐ Test ☐
Municipal ☑ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☑
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Tan sandy clay		0	5	5
Red clay		5	6	1
Dark Brown clay		6	20	14
Green Hard Rock	✓	20	143	123

RECEIVED 00 SEP 15 AM 11:21 STATE ENGINEERS OFFICE

Date started 11/18/, 1985
Date completed ~~[illegible]~~ 1-10, 1986

7. WELL TEST DATA

~~Pump RPM~~	G.P.M.	~~Draw Down~~	~~After Hours Pump~~
Air lift	2 hrs APPR. 300 GPM		

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter hole 12¼ inches Total depth 143 feet
Casing record
Weight per foot ~~.250~~ .19 Thickness .250

Diameter	From	To
8 5/8 inches	0 feet	102 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☑ No ☐ Type pumped grout
Depth of seal 102 feet
Gravel packed: Yes ☑ No ☐
Gravel packed from 102 feet to 143 feet

Perforations:
Type perforation Factory sawed
Size perforation 3-32 X 2½ X 4 row
From ..... feet to ..... feet
From ..... feet to ..... feet
From 123 feet to 143 feet
From ..... feet to ..... feet
From ..... feet to ..... feet

9. WATER LEVEL
Static water level 20 feet below land surface
Flow ~~G.P.M.~~ APPR. 300 ~~P.S.I.~~
Water temperature WARM F. Quality unknown

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Paul Williams & Son
Contractor
Address 22 So Patterson, Spark, Nev
Contractor
Nevada contractor's license number 14485
Nevada contractor's drillers number 958
Nevada driller's license number 1460
Actual Driller
Signed Paul Williams Sr.
Contractor
Date 11-19-85

USE ADDITIONAL SHEETS IF NECESSARY

(Rev. 6-81) O-627 CR434