WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 81754
Permit No.
Basin 101

NOTICE OF INTENT NO. 44828

1. OWNER MIKE CASEY
MAILING ADDRESS 1550 ALLEN ROAD
FALLON, NV 89406

ADDRESS AT WELL LOCATION 7500 ANNETTE, Fallon

2. LOCATION SE 1/4 SE 1/4 Sec. 1 T 19 N/S R 27 E CHURCHILL County
PERMIT NO. Issued by Water Resources
7-122-07 Parcel No.
VANESSA Subdivision Name

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[X] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
BRN SAND		0	5	5
BRN CLAY		5	10	5
BRN SAND		10	20	10
BRN CLAY		20	22	2
GREY SAND		22	38	16
HARD PAN/CLAY		38	42	4
GREY SAND		42	55	13
GREY CLAY		55	58	3
BLK GRAVEL		58	63	5
GREY CLAY		63	65	2
GREY GRAVELS	X	65	70	5

Date started 9/12/2000, 19__
Date completed 9/12/2000, 19__

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
20		1 HR

8. WELL CONSTRUCTION
Depth Drilled 70 Feet Depth Cased 70 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10 5/8	Inches	0	Feet	50	Feet
6 5/8	Inches	50	Feet	70	Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.9	.188	+2	70

Perforations:
Type perforation MACHINE SLIT
Size perforation .080
From 66 feet to 68 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50
Placement Method: [X] Pumped [ ] Poured
Seal Type: [ ] Neat Cement [X] Cement Grout [ ] Concrete Grout

Gravel Packed: [ ] Yes [X] No
From feet to feet

9. WATER LEVEL
Static water level 11' feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature COOL °F Quality SOME ODOR

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name WELSCO CORP. Contractor
Address P. O. BOX 888 Contractor
FALLON, NV 89406
Nevada contractor's license number issued by the State Contractor's Board 11752
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1996
Signed [signature] By driller performing actual drilling on-site or contractor
Date 9/24/2000

USE ADDITIONAL SHEETS IF NECESSARY