WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 81759
Permit No. 60497
Basin 1

NOTICE OF INTENT NO. 41821

1. OWNER John O'Brian
MAILING ADDRESS P.O Box 231
Winnemucca NV 89446

ADDRESS AT WELL LOCATION 5900 Klumey Canyon Road
Winnemucca, NV 89445

2. LOCATION SE ¼ NE ¼ Sec. 28 T. 36 N/S R. 38 E. Humbolt County

PERMIT NO. 60497 (Issued by Water Resources) | 021467 (Parcel No.) | Nowe (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☒ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Topsoil		0	10	10
Rock Boulders		10	70	60
Gravel + Sand Boulders		70	100	30
Clay		100	135	35
Solid Rock		135	180	45
Sand + Gravel	Yes	180	200	20
Solid Rock		200	290	90
Clay + Boulders		290	320	30
Sand + Fine Gravel	Yes	320	396	76

Date started 7-20 2000
Date completed 7-29 2000

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
74		4

8. WELL CONSTRUCTION
Depth Drilled 396' Feet Depth Cased 396' Feet

HOLE DIAMETER (BIT SIZE)

		From	To
12 5/8 Inches		0 Feet	396' Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8 5/8		1.88	+1	396'

Perforations:
Type perforation Factory Cut
Size perforation 3/32x4
From 180 feet to 200 feet
From 320 feet to 396 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 55
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 55 feet to 396' feet

9. WATER LEVEL
Static water level feet below land surface
Artesian flow N/A G.P.M. N/A P.S.I.
Water temperature Cool °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Fred Andersen + Son Drilling (Contractor)
Address 10760 Grass Valley Rd (Contractor)
Winn NV 89445
Nevada contractor's license number issued by the State Contractor's Board 021467
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2083
Signed (By driller performing actual drilling on site or contractor)
Date Sept 07-00

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627