WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

# WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 81760
Permit No. 66699
Basin 212

NOTICE OF INTENT NO. 21545

1. OWNER William Gibson
MAILING ADDRESS 6800 W. Gary Las Vegas Nev.
ADDRESS AT WELL LOCATION 6800 W. Gary AVE

2. LOCATION SW ¼ SW ¼ Sec. 23 T. 22 N/S R. 60 E. Clark County
PERMIT NO. 66699 (Issued by Water Resources) 17623401 007 (Parcel No.) Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☒ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| Brn Clays Bldrs + gravels | | 0 | 450 | 450 |
| Red sandstone | | 450 | 505 | 55' |
| Yellow Sand Stone | X | 505 | 515 | 10' |
| Gravels w/ Stringers of Bldrs | | 515 | 600 | 85' |

Date started 9-5 2000
Date completed 9-11 2000

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

| | G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|---|---|---|
| 20 gpm 950 @ 350 | | | 30 min |

8. WELL CONSTRUCTION
Depth Drilled 600 Feet Depth Cased 575 Feet

HOLE DIAMETER (BIT SIZE)

| | From | To |
|---|---|---|
| 10 Inches | 0 Feet | 600 Feet |
| Inches | Feet | Feet |
| Inches | Feet | Feet |

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|---|---|---|---|---|
| 6" | Certainteed | Sch 40 | +1 | 575 |
| 8" | | .188 | +1 | 6' |

Perforations:
Type perforation Saw
Size perforation 1/8 x 8"
From 575 feet to 515 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 55'
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 55 feet to 600' feet

9. WATER LEVEL
Static water level 460 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature Cool °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Redding Drilling (Contractor)
Address 3955 Blue Diamond Rd #4 (Contractor)
Las Vegas, NV. 89139
Nevada contractor's license number issued by the State Contractor's Board 38155
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2131
Signed [signature] By driller performing actual drilling on site or contractor
Date 9-11-00

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627