WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 81762
Permit No.
Basin 101

NOTICE OF INTENT NO. 41704

1. OWNER Tim & Shannon Myers
MAILING ADDRESS 2860 Harrigan Road
Fallon, NV 89406

ADDRESS AT WELL LOCATION 2860 Harrigan Road,
Fallon, NV 89406

2. LOCATION SE 1/4 SE 1/4 Sec. 6 T 18N N/S R 29E E Churchill County
PERMIT NO. _____ Issued by Water Resources | 006-741-45 Parcel No. | Subdivision Name

3. **WORK PERFORMED**
☐ New Well ☒ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. **PROPOSED USE**
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. **WELL TYPE**
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. **LITHOLOGIC LOG**

Material	Water Strata	From	To	Thickness
Brown Sand		0	10	10
Brown Clay		10	14	4
Fine Brown Sand		14	21	7
Brown Clay		21	35	14
Gray Sand		35	43	8
Black Sand		43	96	53
Brown Clay		96	103	7
Brown Sand	XX	103	118	15

RECEIVED
00 SEP 14 AM 10:45
STATE ENGINEER'S OFFICE

Date started 07/14/2000, 19__
Date completed 07/15/2000, 19__

7. **WELL TEST DATA**
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
30		1 hr

8. **WELL CONSTRUCTION**
Depth Drilled 118 Feet Depth Cased 118 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10 Inches	0 Feet	118 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.96	.188	0	10
6 PVC	3.92	.258	10	118

Perforations:
Type perforation Saw Cut
Size perforation 1/8
From 113 feet to 116 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 100
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☒ Cement Grout ☐ Concrete Grout
Gravel Packed: ☐ Yes ☒ No
From 100 feet to 118 feet

9. **WATER LEVEL**
Static water level 17 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature cool °F Quality unknown

10. **DRILLER'S CERTIFICATION**
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Parsons Drilling, Inc.
Contractor
Address P.O. Box 1264
Contractor
Fallon Nv. 89407

Nevada contractor's license number issued by the State Contractor's Board 29064

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1753

Signed Wayne Parsons
By driller performing actual drilling on-site or contractor

Date 08/03/2000

USE ADDITIONAL SHEETS IF NECESSARY